

COURT OF APPEAL, FOURTH APPELLATE DISTRICT DIVISION TWO

QUESTIONS AND ANSWERS

RFP NO. 4/2 RFP 12/13-02CK

JANITORIAL SERVICES

December 17, 2012

1. Question: How many fire sprinkler risers are in the building?

Answer: 1.

2. Question: How many waterflow and tamper switches?

Answer: (2) Water flows & (6) Tamper.

3. Question: Is there only one fire pump? Electric or Diesel? How many GPM?

Answer: (1) Diesel- 500 GPM

4. Question: How many PIV's on the property?

Answer: No PIV's, but (2) Main OS&Y's