

# SUPREME COURT OF CALIFORNIA

## QUESTIONS AND ANSWERS

**IFB Number: IFB-Supreme-041516-MDS**

### California Supreme Court New High Density File Storage

April 19, 2016

---

1. In the IFB, Section 1.2, Background Information, it states that capacity of 3,400 lineal feet is for legal size documents. But in the Specifications – General Section, it states that the shelving depth is 12”, which is letter size. Please confirm if you want letter size (12” deep) shelving or legal size (15” deep) shelving.

**Answer:** The Specifications –General Section is correct. The Supreme Court of California is only seeking 12”, letter size shelving. Section 1.2 will be revised via an Addendum to IFB-Supreme-041516-MDS to read, “The Supreme Court of California has a need to and will expand its file storage capacity at 350 McAllister Street, San Francisco, California with a new high density file storage system with a capacity of 3,400 lineal feet of letter size documents.”

2. How many dividers per shelf will be required? If so, what height (6” or 9”)?

**Answer:** No dividers will be required per shelf.

3. Will there be a need to have a Structural Engineer do Seismic Calculations?

**Answer:** Yes, the Vendor is responsible for having a Structural Engineer measure the Seismic Calculations for this installation.

4. Should any room be allowed for growth from the required 3,400 lineal feet?

**Answer:** No.

*[END OF QUESTIONS AND ANSWERS]*