



## Guidelines for Passenger Elevators

Elevators provided for passengers shall comply with **11B-206.6 and 11B-407**. Where multiple elevators are provided, each elevator shall comply with **11B-407**.

### 1 General – 11B-407.1

- 1) Elevators shall be passenger elevators as classified by **ASME A17.1** and shall comply with **11B-407** and with **ASME A17.1**.
- 2) Elevator operation shall be automatic.
- 3) When the only elevators provided for use by the public and employees are combination passenger and freight elevators, they shall comply with **11B-407** and **ASME A17.1**.

### 2 Elevator landing requirements – 11B-407.2 and 1007

- 1) Call controls – Where elevator call buttons or keypads are provided, they shall comply with **11B-407.2.1** and **11B-309.4**.
  - Height - Call buttons and keypads shall be located within one of the reach ranges specified in **11B-308**, measured to the centerline of the highest operable part.
  - Size and shape - Call buttons shall have square shoulders, be 3/4 inch minimum in the smallest dimension and shall be raised 1/8 inch plus or minus 1/32 inch above the surrounding surface. The buttons shall be activated by a mechanical motion that is detectable.
  - Clear floor or ground space - A clear floor or ground space complying with **11B-305** shall be provided at call controls.
  - Location - The call button that designates the up direction shall be located above the call button that designates the down direction.
  - Signals - Call buttons shall have visible signals that will activate when each call is registered and will extinguish when each call is answered. Call buttons shall be internally illuminated with a white light over the entire surface of the button.
  - Keypads - Keypads, where provided, shall be in a standard telephone keypad arrangement and shall comply with **11B-407.4.7.2**.
- 2) Hall signals – Hall signals, including in-car signals, shall comply with **11B-407.2.2**.
  - Visible and audible signals - A visible and audible signal shall be provided at each hoistway entrance to indicate which car is answering a call and the car's direction of travel. Where in-car signals are provided, they shall be visible from the floor area adjacent to the hall call buttons.
  - Visible signals – Visible signal fixtures shall be centered at 72 inches minimum above the finish floor or ground. The visible signal elements shall be a minimum 2 1/2 inches high by 2 1/2 inches wide. Signals shall be visible from the floor area adjacent to the hall call button.
  - Audible signals – Audible signals shall sound once for the up direction and twice for the down direction, or shall have verbal annunciators that indicate the direction of elevator car travel. Audible signals shall have a frequency of 1500 Hz maximum. Verbal annunciators shall have a frequency of 300 Hz minimum and 3000 Hz maximum. The audible signal and verbal annunciator shall be 10 dB minimum above ambient, but shall not exceed 80 dB, measured at the hall call buttons.
- 3) Hoistway signs – Signs at elevator hoistways shall comply with **11B-407.2.3**.
  - Floor designation – Floor designations complying with **11B-703.2** and **11B-703.4.1** shall be provided on both jambs of elevator hoistway entrances. Floor designations shall be provided in both raised characters and Braille. Raised characters shall be 2 inches high. A raised star, placed to the left of the floor designation, shall be provided on both jambs at the main entry level. The outside diameter of the star shall be 2 inches and all points shall be of equal length. Raised characters, including the star, shall be white on a black background. Braille complying with **11B-703.3** shall be placed below the corresponding raised characters and the star. The Braille translation for the star shall be "MAIN". Applied plates are acceptable if they are permanently fixed to the jamb.
- 4) Two-way communication – 1009.8
  - Provide a two-way communication system with both audible and visible signals at the elevator landing on each accessible floor that is one or more stories above or below the story of exit discharge. Such systems are not required at elevator landings where they are provided within areas of refuge in accordance with **1009.6.3**.
  - Directions for the use of the two-way communication system and the instructions for summoning assistance via such system and written identification of the specific story, floor location and building address or other building identifier shall be posted adjacent to the two-way communication system. **1009.8.2**

*(Show plan reviewer, on floor plans and elevations, with reference to details, the locations and contents of such posted directions)*

### 5) Directional signage - 1009.10

- Provide a directional signage complying with **11B-703.5** at elevator landings indicating the locations of the other means of egress and which are accessible means of egress.

### 3 Elevator door requirements – 11B-407.3

- 1) Type – Elevator doors shall be the horizontal sliding type. Car gates shall be prohibited.
- 2) Operation – Elevator hoistway and car doors shall open and close automatically.
- 3) Reopening device – Elevator doors shall be provided with a reopening device complying with **11B-407.3.3** that shall stop and reopen a car door and hoistway door automatically if the door becomes obstructed by an object or person.
- 4) Height – The device shall be activated by sensing an obstruction passing through the opening at 5 inches nominal and 29 inches nominal above the finish floor.
- 5) Contact – The device shall not require physical contact to be activated, although contact is permitted to occur before the door reverses.
- 6) Duration – Door reopening devices shall remain effective for 20 seconds minimum.
- 7) Door and signal timing – The minimum acceptable time from notification that a car is answering a call until the doors of that car start to close shall be calculated from the following equation:

- $$T = D/(1.5 \text{ ft/s}) \text{ or } T = D/(457 \text{ mm/s}) = 5 \text{ seconds minimum where}$$
- T* equals the total time in seconds and *D* equals the distance (in feet or millimeters) from the point in the lobby or corridor 60 inches directly in front of the farthest call button controlling that car to the centerline of its hoistway door.
- 8) Door delay – Elevator doors shall remain fully open in response to a car call for 5 seconds minimum.
  - 9) Width – The width of elevator doors shall comply with **Table 11B-407.4.1**.

### 4 Elevator car requirements – 11B-407.4


- 1) Car dimensions – Inside dimensions of elevator cars and clear width of elevator doors shall comply with **Table 407.4.1**. Where elevators are provided in buildings four or more stories above, or four or more stories below, grade plane, not fewer than one elevator shall be provided for fire department emergency access to all floors (80 x 54 inside car dimensions or otherwise accommodate requirement) per **3002.4** and **3002.4.3a**.
- 2) Floor surfaces – Floor surfaces in elevator cars shall comply with **11B-302** and **11B-303**.
- 3) Platform to hoistway clearance – The clearance between the car platform sill and the edge of any hoistway landing shall be 1 1/4 inches maximum.
- 4) Leveling – Each car shall be equipped with a self-leveling feature that will automatically bring and maintain the car at floor landings within a tolerance of 1/2 inch under rated loading to zero loading conditions.
- 5) Illumination – The level of illumination at the car controls, platform, car threshold and car landing sill shall be 5 foot candles minimum.
- 6) Elevator car controls – Where provided, they shall comply with **11B-407.4.6** and **11B-309.4**.
  - Location – Controls shall be located within one of the reach ranges specified in **11B-308**.
  - Buttons – Car control buttons with floor designations shall comply with the following:
    - Size and Shape – Buttons shall have square shoulders, be 3/4 inch minimum in the smallest dimension and be raised 1/8 inch plus or minus 1/32 inch above the surrounding surface.
    - Arrangement – Buttons shall be arranged with numbers in ascending order. When two or more columns of buttons are provided they shall read from left to right.
    - Illumination – Car control buttons shall be illuminated.
    - Operation – Car control buttons shall be activated by a mechanical motion that is detectable.
  - Keypads – Car control keypads shall be in a standard telephone keypad arrangement and shall comply with **11B-407.4.7.2**.
  - Emergency controls – Emergency controls shall comply with **11B-407.4.6.4**.
    - Height – Emergency control buttons shall have their centerlines 35 inches minimum above the finish floor.
    - Location – Emergency controls, including the emergency alarm, shall be grouped at the bottom of the panel.
- 7) Designations and indicators of car controls – they shall comply with **11B-407.4.7**.
  - Buttons – Car control buttons shall comply with **11B-407.4.7.1**.
    - Type – Control buttons shall be identified by raised characters or symbols, white on a black background, complying with **11B-703.2** and Braille complying with **11B-703.3**.
    - Location – Raised characters or symbols and Braille designations shall be placed immediately to the left of the control button to which the designations apply.
    - Symbols – The control button for the emergency stop, alarm, door open, door close, main entry floor, and phone, shall be identified with raised symbols and Braille as shown in **Table 11B-407.4.7.1.3**.
    - Visible indicators – Buttons with floor designations shall be provided with visible indicators to show that a call has been registered. The visible indication shall extinguish when the car arrives at the designated floor.
    - Button spacing – A minimum clear space of 3/8 inch or other suitable means of separation shall be provided between rows of control buttons.
  - Keypads – Keypads shall be identified by characters complying with **11B-703.5** and shall be centered on the corresponding keypad button. The number five key shall have a single raised dot. The dot shall be 0.118 inch to 0.120 inch base diameter and in other aspects comply with **Table 11B-703.3.1**.
- 8) Car position indicators – Audible and visible car position indicators shall be provided in elevator cars.
  - Visible indicators – Visible indicators shall comply with **11B-407.4.8.1**.
    - Size – Characters shall be 1/2 inch high minimum.
    - Location – Indicators shall be located above the car control panel or above the door.
    - Floor arrival – As the car passes a floor and when a car stops at a floor served by the elevator, the corresponding character shall illuminate.
  - Audible indicators – Audible indicators shall comply with **11B-407.4.8.2**.
    - Signal type – The signal shall be an automatic verbal annunciator which announces the floor at which the car is about to stop.
    - Signal level – The verbal annunciator shall be 10 dB minimum above ambient, but shall not exceed 80 dB, measured at the annunciator.
    - Frequency – The verbal annunciator shall have a frequency of 300 HZ minimum to 3000 HZ maximum.
- 9) Emergency communication – Emergency two-way communication systems shall comply with **11B-308**. Raised symbols or characters, white on a black background, and Braille shall be provided adjacent to the device and shall comply with **11B-703.2** and **11B-703.3**. Emergency two-way communication systems between the elevator and a point outside the hoistway shall comply with **ASME A17.1**.
- 10) Support rail – Support rails shall be provided on at least one wall of the car.
  - Location – Clearance between support rails and adjacent surfaces shall be 1 1/2 inches minimum. Top of support rails shall be 31 inches minimum to 33 inches maximum above the floor of the car. The ends of the support rail shall be 6 inches maximum from adjacent walls.
  - Surfaces – Support rails shall be smooth and any surface adjacent to them shall be free of sharp or abrasive elements.
  - Structural strength – Allowable stresses shall not be exceeded for materials used when a vertical or horizontal force of 250 pounds is applied at any point on the support rail, fastener, mounting device, or supporting structure.

REV	DATE	DESCRIPTION
	7/14/2016	100% SD
	8/4/2016	100% DD
	9/13/2016	50% CD
	11/08/2016	90% CD
	03/09/2017	PERMIT SET
	06/14/2017	100% CD/CONFORMED SET

EAST COUNTY  
COURTHOUSE  
ELEVATOR MODERNIZATION  
250 E Main St, El Cajon, CA 92020



GUIDELINES FOR  
PASSENGER  
ELEVATORS



**1** SITE PLAN - GROUND FLOOR  
 1/16" = 1'-0"

REV DATE	DESCRIPTION
7/14/2016	100% SD
8/4/2016	100% DD
9/13/2016	50% CD
11/08/2016	90% CD
03/09/2017	PERMIT SET
06/14/2017	100% CD/CONFORMED SET


**EAST COUNTY COURTHOUSE  
 ELEVATOR MODERNIZATION**  
 250 E Main St, El Cajon, CA 92020




**SITE PLAN**

1/16" = 1'-0"

**A1.00**





REV	DATE	DESCRIPTION
	9/05/2016	100% SD
	9/27/2016	100% DD


**STANLEY MOSK  
 COURTHOUSE  
 ELEVATOR MODERNIZATION**  
 1111 N Hill St, Los Angeles, CA 90012


TYPICAL FLOOR PLAN  
 FLOORS 1,2,3,4,7,8

1/16" = 1'-0"

**A2.01**

1 TYPICAL FLOOR PLAN, FLOORS 1,2,3,4,5,7,8  
 1/16" = 1'-0"





REV	DATE	DESCRIPTION
	9/05/2016	100% SD
	9/27/2016	100% DD


**STANLEY MOSK COURTHOUSE  
 ELEVATOR MODERNIZATION**  
 111 N Hill St, Los Angeles, CA 90012


TYPICAL MEZZANINE PLAN  
 FLOORS GM, 1M, 2M, 3M, 4M

1/16" = 1'-0"


**A2.01M**

**1** TYPICAL MEZZANINE FLOOR PLAN, GM, 1M, 2M, 3M, 4M  
 1/16" = 1'-0"





**1** SIXTH FLOOR PLAN  
 1/16" = 1'-0"




REV	DATE	DESCRIPTION
	7/14/2016	100% SD
	8/4/2016	100% DD
	9/13/2016	50% CD
	11/08/2016	90% CD
	03/09/2017	PERMIT SET
	06/14/2017	100% CD/CONFORMED SET


**EAST COUNTY  
 COURTHOUSE  
 ELEVATOR MODERNIZATION**  
 250 E Main St, El Cajon, CA 92020



**SIXTH FLOOR PLAN**



1 NINTH FLOOR PLAN  
 1/16" = 1'-0"




REV	DATE	DESCRIPTION
	7/14/2016	100% SD
	8/4/2016	100% DD
	9/13/2016	50% CD
	11/08/2016	90% CD
	03/09/2017	PERMIT SET
	06/14/2017	100% CD/CONFORMED SET

**EAST COUNTY COURTHOUSE**  
**ELEVATOR MODERNIZATION**  
 250 E Main St, El Cajon, CA 92020




**NINTH FLOOR PLAN**

1/16" = 1'-0"  
**A2.09**



1 TENTH FLOOR PLAN  
 1/16" = 1'-0"

NOTE: NO ELEVATOR ACCESS TO 10TH FLOOR



REV	DATE	DESCRIPTION
	7/14/2016	100% SD
	8/4/2016	100% DD
	9/13/2016	50% CD
	11/08/2016	90% CD
	03/09/2017	PERMIT SET
	06/14/2017	100% CD/CONFORMED SET


**EAST COUNTY COURTHOUSE**  
**ELEVATOR MODERNIZATION**  
 250 E Main St, El Cajon, CA 92020




TENTH FLOOR PLAN

1/16" = 1'-0"  
**A2.10**







**4** ELEVATORS 1, 2, AND 3 MACHINE ROOM  
 1/4" = 1'-0"




**3** ELEVATORS 5 AND 6 MACHINE ROOM  
 1/4" = 1'-0"



**2** ELEVATORS 7, 9, AND 10 MACHINE ROOM  
 1/4" = 1'-0"



**1** ELEVATOR 8 MACHINE ROOM  
 1/4" = 1'-0"




REV DATE	DESCRIPTION
7/14/2016	100% SD
8/4/2016	100% DD
9/13/2016	50% CD
11/08/2016	90% CD
03/09/2017	PERMIT SET
06/14/2017	100% CD/CONFORMED SET


**EAST COUNTY COURTHOUSE**  
**ELEVATOR MODERNIZATION**  
 250 E Main St, El Cajon, CA 92020



**ELEVATOR MACHINE ROOM PLANS**




12 JUDGES ELEVATOR 8 CAB ELEVATIONS  
1/2" = 1'-0"




6 JUDGES ELEVATOR 8  
1/2" = 1'-0"

3 JUDGES ELEVATOR 8  
1/2" = 1'-0"




11 SERVICE ELEVATOR 10 CAB ELEVATIONS  
1/2" = 1'-0"




5 SERVICE ELEVATOR 10 RCP  
1/2" = 1'-0"

2 SERVICE ELEVATOR 10  
1/2" = 1'-0"



10 PUBLIC ELEVATORS 1,2,3,5, AND 6 CAB ELEVATIONS  
1/2" = 1'-0"



4 PUBLIC ELEVATORS 1,2,3,5, AND 6 RCP  
1/2" = 1'-0"

1 PUBLIC ELEVATORS 1,2,3,5, AND 6  
1/2" = 1'-0"

NOTE: NO CAB FINISH WORK ON CUSTODY ELEVATORS 7 OR 9

NOTE: PANELS SHALL NOT BE THICKER THAN (E) PANELS OR DECREASE SIZE OF (E) ELEVATOR INTERIOR DIMENSIONS


REV	DATE	DESCRIPTION
100%	SD	7/14/2016
100%	DD	8/4/2016
50%	CD	9/13/2016
90%	CD	11/08/2016
PERMIT SET		03/09/2017
100% CD/CONFORMED SET		06/14/2017

EAST COUNTY COURTHOUSE  
ELEVATOR MODERNIZATION  
250 E Main St, El Cajon, CA 92020




ELEVATOR CAB INTERIOR ELEVATIONS

NOTE: NO CAB FINISH WORK ON CUSTODY ELEVATORS 7 OR 9




EAST




NORTH


NOTE: RETAIN (E) FINISHES




WEST



SOUTH




5 CUSTODY ELEVATOR 9 RCP  
1/2" = 1'-0"




2 CUSTODY ELEVATOR 9  
1/2" = 1'-0"

11 CUSTODY ELEVATOR 9 INTERIOR CAB ELEVATIONS  
1/2" = 1'-0"

NOTE: NO CAB FINISH WORK ON CUSTODY ELEVATORS 7 OR 9




SOUTH




EAST


NOTE: RETAIN (E) FINISHES




NORTH



WEST



4 CUSTODY ELEVATOR 7 RCP  
1/2" = 1'-0"




1 CUSTODY ELEVATOR 7  
1/2" = 1'-0"

10 CUSTODY ELEVATOR 7 INTERIOR CAB ELEVATIONS  
1/2" = 1'-0"


REV	DATE	DESCRIPTION
100%	SD	7/14/2016
100%	DD	8/4/2016
50%	CD	9/13/2016
90%	CD	11/08/2016
PERMIT SET		03/09/2017
100%CD/CONFORMED SET		06/14/2017

**EAST COUNTY COURTHOUSE**  
**ELEVATOR MODERNIZATION**  
 250 E Main St, El Cajon, CA 92020




**ELEVATOR CAB INTERIOR ELEVATIONS**


1/2" = 1'-0"  
**A5.02**




12 CEILING SECTION - SERVICE CABS  
6" = 1'-0"




9 CORNER REVEAL - SERVICE CABS  
6" = 1'-0"




6 CEILING SECTION  
6" = 1'-0"




3 CORNER REVEAL  
6" = 1'-0"




11 HANDRAIL - SERVICE CABS  
6" = 1'-0"




8 REVEAL - SERVICE CABS  
6" = 1'-0"




5 HANDRAIL  
6" = 1'-0"




2 REVEAL  
6" = 1'-0"




10 BASE - SERVICE CABS  
6" = 1'-0"



7 FRONT REVEAL - SERVICE CABS  
6" = 1'-0"



4 BASE  
6" = 1'-0"




1 FRONT REVEAL  
6" = 1'-0"

REV DATE	DESCRIPTION
7/14/2016	100% SD
8/4/2016	100% DD
9/13/2016	50% CD
11/08/2016	90% CD
03/09/2017	PERMIT SET
06/14/2017	100% CD/CONFORMED SET

EAST COUNTY COURTHOUSE  
ELEVATOR MODERNIZATION  
250 E Main St, El Cajon, CA 92020




ELEVATOR DETAILS  
1/2" = 1'-0"



12 GURNEY ELEVATOR  
1/2" = 1'-0"


**HALL BRAILLE PLATES**

2 1/2" X 3 1/2" CAST PLATES WITH WHITE TACTILE CHARACTERS ON BLACK BACKGROUND. MEETS ASME A17.1 70% CONTRAST REQUIREMENTS. ADHERED FROM BACK SIDE. INCLUDES ARABIC OR N.E.I.I. DESIGNATIONS AND BRAILLE. EGRESS LEVEL TO BE INDICATED WITH A 2" DIAMETER STAR TO THE LEFT OF THE CHARACTER PER CURRENT EDITION OF CBC.




6 HALL BRAILLE DETAIL  
NTS


**CAR BRAILLE PLATES** 1 1/2" DIAMETER CAST PLATES WITH WHITE CHARACTERS ON BLACK BACKGROUND, NEXT TO BUTTONS. MEETS ASME A17.1 70% CONTRAST REQUIREMENTS. ADHERED FROM BACK SIDE. INCLUDES ARABIC OR N.E.I.I. DESIGNATIONS AND BRAILLE. EGRESS LEVEL TO BE INDICATED WITH A STAR TO THE LEFT OF THE CHARACTER PER THE CURRENT EDITION OF CBC.



3 CAR BRAILLE DETAIL  
NTS



10 TYPICAL MAIN APPLIED RETURN  
1" = 1'-0"



7 TYPICAL HALL BUTTON AND BRAILLE PLATE LOCATIONS  
1" = 1'-0"



REV	DATE	DESCRIPTION
	7/14/2016	100% SD
	8/4/2016	100% DD
	9/13/2016	50% CD
	11/08/2016	90% CD
	03/09/2017	PERMIT SET
	06/14/2017	100% CD/CONFORMED SET

EAST COUNTY COURTHOUSE  
ELEVATOR MODERNIZATION  
250 E Main St, El Cajon, CA 92020




SIGNAGE DETAILS  
AS SHOWN

A7.02







**LOAD SUMMARY SDPE**



EXIST DIST PNL ELPA	LOAD VA	LOAD AMPS
EXIST ELEV #1	38226	46
EXIST ELEV #2	38226	46
EXIST ELEV #3	38226	46
EXIST ELEV #8	38226	46
<b>EXIST DIST PNL ELPB</b>		
EXIST ELEV #5	38226	46
EXIST ELEV #6	38226	46
<b>EXIST DIST PNL ELPC</b>		
EXIST ELEV #7	38226	46
EXIST ELEV #9	38226	46
EXIST ELEV #10	38226	46
<b>TOTAL REMOVED LOAD</b>	<b>344034</b>	<b>414</b>

NEW DIST PNL ELPA	LOAD VA	LOAD AMPS
NEW ELEV #1 (24HP)	29085	35
NEW ELEV #2 (24HP)	29085	35
NEW ELEV #3 (24HP)	29085	35
<b>NEW DIST PNL ELPB</b>		
NEW ELEV #5 (24HP)	29085	35
NEW ELEV #6 (24HP)	29085	35
NEW ELEV #8 (24HP)	29085	35
NEW PNL 9PE VIA XFMR	29789	36
<b>NEW DIST PNL ELPC</b>		
NEW ELEV #7 (46HP)	48198	58
NEW ELEV #9 (31HP)	35733	43
NEW ELEV #10 (31HP)	35733	43
<b>TOTAL ADDED LOAD</b>	<b>323963</b>	<b>390</b>

- GENERAL NOTES**
- ALL EQUIPMENT, AND WIRING IS EXISTING UNLESS NOTED OTHERWISE.
  - FEEDER LENGTH SHOWN IS FOR VOLTAGE DROP CALCULATIONS AND PLAN CHECK PURPOSE ONLY. NOT FOR COST ESTIMATING PROCESSES. ALL CONDUCTORS SHALL BE CU.
  - DISCONNECTS FEEDING ELEVATORS, ELEVATOR CAB LIGHTS/FAN AND ESCALATORS SHALL BE FUSED LOCKABLE DISCONNECT SWITCHES.

- SPECIFIC NOTES**
- NEW SHUNT TRIP BREAKER. CONNECT TO HEAT DETECTOR IN CORRESPONDING ELEVATOR MACHINE ROOM VIA 1/2" C. WITH CONTROL WIRES. PROVIDE 120VOLT NORMAL POWER TO SHUNT TRIP. CIRCUIT IS AS FOLLOWS:  
  
FOR ELPA, CONNECT 2#12+1#12G., 3/4" C.O. TO SPARE 20A, 1P IN PANEL 6PE  
FOR ELPB, CONNECT 2#12+1#12G., 3/4" C.O. TO CIRCUIT #34 IN PANEL 9PE  
FOR ELPC, CONNECT 2#12+1#12G., 3/4" C.O. TO CIRCUIT #36 IN PANEL 9PE
  - PROVIDE PULLBOX. INTERCEPT EXISTING FEEDER AND CONDUIT AND EXTEND TO NEW LOCATION. PROVIDE WIRE AND CONDUIT AS INDICATED.
  - DEMOLISH EXISTING DISTRIBUTION BOARD, BREAKERS, AND GROUNDING. REPLACE WITH NEW DISTRIBUTION PANELBOARD AS INDICATED.



**PANEL NAME: 9PE**

Bus Cu Type: 208/120V, 10kVAC, 3PH, 4W  
 PHASE & WIRE: BUS: 225  
 FED FROM: ELPB MA 30KVA XFMR  
 BUS: 225  
 FED FROM AMPS: 100  
 LUGS: SINGLE

CIRCUIT NO	TRIP	POLE	DESCRIPTION	MISC	REC	LOAD (VA)	PHASES (VA)	A	B	C	LOAD (VA)	REC	MISC	DESCRIPTION	POLE	TRIP	CODE	NO
1	20	1	SPARE			1040					1040			HP-5, AHU-5	2	20	2	2
3	20	1	SPARE							1040	1040			with circuit above	-	-	2	4
5	20	1	SPARE							1000	1000			AHU-5.6 CONDENSATE PUMPS	1	20	2	6
7	20	1	SPARE			1297					1297			AHU-10	3	20	2	8
9	20	1	SPARE			1297				1297	1297			with circuit above	-	-	2	10
11	20	1	SPARE			1297				1297	1297			with circuit above	-	-	2	12
13	20	1	SPARE			200				200	200			ELEV CAB LIGHTS AND FAN	1	20	1	14
15	20	1	SPARE							200	200			AHU-9 CONDENSATE PUMP	1	20	2	16
17	20	1	SPARE			1882				1882	1882			AHU-6, HP-6	2	30	2	18
19	20	1	SPARE			1882				1882	1882			with circuit above	-	-	2	20
21	20	1	SPARE			4563				4563	4563			HP-10	3	60	2	22
23	20	1	SPARE			4563				4563	4563			with circuit above	-	-	2	24
25	20	1	SPARE			4563				4563	4563			with circuit above	-	-	2	26
27	20	1	SPARE			200				200	200			AHU-10 CONDENSATE PUMP	1	20	2	28
29	20	1	SPARE			1882				1882	1882			AHU-9, HP-9	2	20	2	30
31	20	1	SPARE			1882				1882	1882			with circuit above	-	-	2	32
33	20	1	SPARE			500				500	500			ELEV 5.6.8 SHUNT TRIP	1	20	2	34
35	20	1	SPARE			500				500	500			ELEV 7.9, 10 SHUNT TRIP	1	20	2	36
37	20	1	SPARE			0				0	0			SPARE	1	20		38
39	20	1	SPARE			0				0	0			SPARE	1	20		40
41	20	1	SPARE			0				0	0			SPARE	1	20		42

**NOTES:**

DEMAND	VA	AMPS	10864	7800	11124
CONN VA	10864	7800	11124		
VA	10914	7800	11124		
AMPS	91	65	93		

CONNECTED KVA	29.8	0.0	0.0	SUM
CONNECTED KVA	29.8	0.0	0.0	30
CONT (CODE 1)	29.8	0.0	0.0	0
N-CONT (CODE 2)	0.0	0.0	0.0	0
RECEP (CODE 3)	0.0	0.0	0.0	0
KITCH (CODE 4)	0.0	0.0	0.0	0
# OF KITCHEN EQ:	0.0			

PANEL DEMAND KVA: 30  
 (MINIMUM PANEL SIZE) DEMAND AMPS: 82  
 MINIMUM XFMR, KVA SIZE: 30

JOB: EAST COUNTY COURTHOUSE  
 BY: LUKE ADACHI  
 ISSUE DATE: 09 09 2016

**CAVAGNERO**  
 ARCHITECTS

**SYSKA HENNESSY group**  
 A member company of SH Group, Inc.  
 Syska Hennessy Group, Inc.  
 800 Corporate Pointe  
 Suite 200  
 Culver City, CA 90230  
 Tel: 310.312.0200  
 Fax: 310.665.0172  
 www.syska.com

**EAST COUNTY COURTHOUSE  
 ELEVATOR MODERNIZATION**  
 250 E Main St, El Cajon, CA 92020

**ELECTRICAL SINGLE LINE DIAGRAM**

**E.003**

REV DATE DESCRIPTION  
 07/14/2016 100% SD  
 08/04/2016 100% DD  
 09/13/2016 50% CD  
 11/08/2016 90% CD  
 01/17/2017 PLAN CHECK #1  
 03/09/2017 PERMIT SET  
 06/14/2017 100% CD / CONFORMED SET



**FIRE ALARM GENERAL NOTES**

- THESE DRAWINGS AND THE SPECIFICATIONS ARE THE CONSTRUCTION DOCUMENTS FOR THE EXISTING EAST COUNTY COURTHOUSE LOCATED AT 250 E. MAIN STREET, SAN DIEGO, CA 92020. ALL INSTALLATION WORK SHALL BE COMPLETED BY A LICENSED ELECTRICAL CONTRACTOR, WHO SHALL BE REFERRED TO AS "CONTRACTOR" WHERE REFERENCED ELSEWHERE WITHIN THESE DOCUMENTS.
- THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING AND INSTALLING ALL FIRE ALARM SYSTEM COMPONENTS & DEVICES/APPLIANCES, WIRING, CONDUIT, MOUNTING HARDWARE, SYSTEM TESTING AND TRAINING. THE CONTRACTOR SHALL ALSO BE RESPONSIBLE FOR SUBCONTRACTING WITH A CERTIFIED FIRE ALARM CONTRACTOR WHO SHALL REPRESENT THE SYSTEM MANUFACTURER TO ENSURE PROPER INSTALLATION, PROGRAMMING, OPERATION, FINAL PANEL WIRING AND MANUFACTURER SUPPORT.
- THE NEW ADDRESSABLE INITIATION DEVICES AND NEW NOTIFICATION APPLIANCES SHALL BE CONNECTED TO THE APPROPRIATE FAS CIRCUITS AT THE TERMINAL BOX SERVING EACH FLOOR. PROVIDE AND INSTALL END OF LINE DEVICES AS REQUIRED. INSTALL LINE ISOLATION MODULES FOR EVERY 50 DEVICES ON EACH ADDRESSABLE INITIATING CIRCUIT. EXACT LOCATIONS OF ISOLATION MODULES SHALL BE DETERMINED IN THE FIELD, DOCUMENTED AND LABELED AS SUCH.
- ALL FIRE ALARM LOW VOLTAGE WIRING SHALL BE CERTIFIED TEFLON JACKETED FIRE ALARM CABLE WHICH MEETS THE REQUIREMENTS OF SECTION 760 OF NFPA 70. FIRE ALARM CABLE SHALL BE PROTECTED IN ACCORDANCE WITH SECTION 760 OF NFPA 70. PROVIDE APPROVED FIRE STOPPING MATERIAL FOR ALL FLOOR, WALL AND BARRIER PENETRATIONS TO MAINTAIN FIRE/SMOKE RATINGS. ALL FAS CONDULETS, JUNCTION BOXES AND TERMINAL BOXES SHALL BE PAINTED IN ACCORDANCE WITH CODE.
- THE BASE CONTRACT SHALL INCLUDE A CONCEALED CONDUIT & CABLE INSTALLATION. ALL FIRE ALARM DEVICES AND FIELD CIRCUITS IN OCCUPIED AREAS ON THE FLOORS, SHALL BE RECESSED AND CONCEALED. SURFACE MOUNTING OF DEVICES AND CONDUIT SHALL BE PERMITTED IN UNOCCUPIED AREAS SUCH AS MACHINE ROOMS, SHAFT WAYS AND OTHER UNOCCUPIED AREAS. ALL SURFACE MOUNTED DEVICE BACK-BOXES SHALL BE THE FINISHED TYPE. REFER TO DETAIL SHEETS FOR FURTHER INFORMATION.
- DURING INSTALLATION THE ELECTRICAL CONTRACTOR SHALL TEST ALL WIRING FOR INTEGRITY (CONDUCTOR TO CONDUCTOR/CONDUCTOR TO GROUND) AFTER EACH PHASE OF WORK AFTER ALL EQUIPMENT IS COMPLETELY INSTALLED, TESTED AND OPERATIONAL, THE FACP SHALL BE PROGRAMMED AND THE WIRING RE-TESTED FOR INTEGRITY.
- NEW ADDRESSABLE HEAT DETECTORS, INSTALLED IN ACCORDANCE WITH NFPA 72, SHALL BE PROVIDED FOR SPRINKLER PROTECTED ELEVATOR HOISTWAYS AND MACHINE ROOMS.
  - THE HEAT DETECTORS IN ELEVATOR HOISTWAYS AND MACHINE ROOMS SHALL BE INSTALLED WITHIN 18" OF EACH SPRINKLER HEAD AND SHALL BE UTILIZED TO ACTIVATE ELEVATOR PHASE-I RECALL AND SHUNT TRIP OPERATIONS. SHUNT TRIP SHALL BE DELAYED SUCH THAT THE ELEVATOR HAS TIME TO RECALL TO THE DESIGNATED OR ALTERNATE FLOOR.
  - THE SPACING OF DEVICES ON THE DRAWINGS ARE BASED UPON 50' SPACING AT 10' MOUNTING HEIGHTS AFF ALONG SMOOTH CEILINGS. ANY DEVIATION SHALL REQUIRE REEVALUATION OF PROPOSED DEVICE LOCATIONS.
- NEW ADDRESSABLE SMOKE DETECTORS, INSTALLED IN ACCORDANCE WITH NFPA 72, SHALL BE PROVIDED IN ELEVATOR MACHINE ROOMS, ELEVATOR LANDINGS, AND THE TOP OF ELEVATOR HOISTWAYS.
  - THE NEW ADDRESSABLE ELEVATOR MACHINE ROOM, LANDING, AND HOISTWAY SMOKE DETECTORS SHALL BE UTILIZED TO ACTIVATE ELEVATOR PHASE-I RECALL. THE DETECTORS SHALL BE CONNECTED TO THE ADDRESSABLE CIRCUIT SERVING THE ZONE.
- IN LOCATIONS WHERE HEAT DETECTORS AND/OR SMOKE DETECTORS ARE REQUIRED, THE TYPE AND/OR TEMPERATURE RATING OF FIRE DETECTOR MAY BE MODIFIED IF THE TYPE OR TEMPERATURE RATING OF THE DEVICE IS UNSUITABLE DUE TO ENVIRONMENTAL OR STRUCTURAL CONDITIONS UNIQUE TO THAT LOCATION OR WHERE MULTIPLE NUISANCE ALARMS ARE LIKELY TO OCCUR.
- INSTALL NEW ADDRESSABLE DUCT MOUNTED SMOKE DETECTORS AS SHOWN ON THE CONTRACT DRAWINGS AND WHERE REQUIRED TO COMPLY WITH THE VUSMC.
  - WHERE A SMOKE DAMPER IS INSTALLED WITHIN A DUCT, A SMOKE DETECTOR SHALL BE INSTALLED IN THE DUCT WITHIN 5' OF THE DAMPER WITH NO AIR OUTLETS OR INLETS BETWEEN THE DETECTOR AND THE DAMPER.
  - SMOKE DETECTORS SHALL BE INSTALLED IN RETURN AIR SYSTEMS WITH A DESIGN CAPACITY GREATER THAN 2,000 CFM, IN THE RETURN AIR DUCT OR PLENUM UPSTREAM OF ANY FILTERS, EXHAUST AIR CONNECTIONS, OUTDOOR AIR CONNECTIONS, OR DECONTAMINATION EQUIPMENT AND APPLIANCES.
- WHERE DUCT-TYPE SMOKE DETECTORS ARE INSTALLED IN HVAC SYSTEMS, THE DUCT-TYPE SMOKE DETECTORS SHALL BE CONNECTED TO THE FIRE ALARM SYSTEM TO SIGNAL AN AUDIBLE AND VISUAL SUPERVISORY SIGNAL AT A CONSTANTLY ATTENDED LOCATION. THE SUPERVISORY SIGNAL AT A CONSTANTLY ATTENDED LOCATION IS NOT REQUIRED WHERE THE DUCT SMOKE DETECTOR ACTIVATES THE BUILDING'S ALARM-INDICATING APPLIANCES.
- FAN SHUTDOWN SHALL BE A FUNCTION OF THE SYSTEM, NOT THE DUCT DETECTOR. CONTRACTOR TO VERIFY FAN SHUTDOWN WIRING WITH BMS AND MECHANICAL CONTRACTORS. PROVIDE INTERPOSING RELAYS AS REQUIRED FOR INTERPOSING VOLTAGES AT THE FAN STARTER CIRCUITS OR BMS PANEL. ADDITIONAL ADDRESSABLE CONTROL MODULES SHALL BE PROVIDED AND INSTALLED (AS OUTPUTS) FOR FIRE ALARM INDICATIONS AND ALSO FOR SEQUENTIAL FAN RESTART. UPON MANUAL COMMAND FROM THE FACP, DUCT MOUNTED SMOKE DETECTORS SHALL BE PROVIDED WITH REMOTE LED/TEST SWITCHES.

- CONTRACTOR TO PROVIDE THE ELEVATOR WITH FIREFIGHTER'S SERVICE AS PER ANSI/ASME A17.1-2010, AS REQUIRED FOR PHASE-I EMERGENCY RECALL OPERATION. PHASE-II EMERGENCY IN-CAR OPERATION SHALL BE A FUNCTION OF THE ELEVATOR CONTROLLER AND IS NOT INCLUDED IN THIS CONTRACT. PROVIDE ADDRESSABLE INTERFACE CONTROL MODULE AND CONTROL RELAY AT THE ELEVATOR CONTROLLER AS INDICATED ON THE DRAWINGS FOR PHASE-I ELEVATOR RECALL. THE ADDRESSABLE CONTROL MODULE FOR PHASE-I ELEVATOR RECALL SHALL BE PROGRAMMED TO ACTIVATE UPON ACTIVATION OF ANY ASSOCIATED ELEVATOR SMOKE DETECTOR OR WATERFLOW DEVICE. COORDINATE CONNECTIONS TO ELEVATOR CONTROLLER WITH THE ELEVATOR CONTRACTOR. CONNECT INTERFACE MODULES TO THE ADDRESSABLE CIRCUIT SERVING FLOOR. PROVIDE WIRING, CONDUIT AND ENCLOSURES REQUIRED.
- PROVIDE ADDRESSABLE INTERFACE CONTROL MODULES AS REQUIRED, FOR THE FOLLOWING EQUIPMENT/SYSTEMS:
  - AT ELEVATOR CONTROLLERS FOR PHASE-1 ELEVATOR RECALL.
  - AT ELEVATOR CIRCUIT-BREAKERS FOR SHUNT TRIP POWER SHUTDOWN.
  - AT HVAC FAN UNIT CONTROLLER FOR FAN SHUT DOWN AND OVERRIDE.
- ALL DEVICES INSTALLED AS DESCRIBED ABOVE SHALL BE PROGRAMMED, TESTED AND MADE FULLY OPERATIONAL AT THE FACP TO IMPLEMENT THE FIRE MANAGEMENT SEQUENCE OF OPERATION AS DESCRIBED IN THE DRAWINGS AND SPECIFICATIONS. THE ENTIRE FIRE ALARM SYSTEM SHALL BE TESTED IN ACCORDANCE WITH NFPA 72 (CHAPTER 14) INSPECTION, TESTING AND MAINTENANCE. THE CONTRACTORS SHALL BE RESPONSIBLE FOR COMMISSIONING A PRE-TEST PRIOR TO AHJ INSPECTION. THE OWNER SHALL BE PERMITTED 3 COMPLETE SYSTEM REPROGRAMMINGS AS PART OF THIS CONTRACT.
- ALL WORK, WIRING, CONDUIT/RACEWAYS AND EQUIPMENT INSTALLATIONS SHALL MEET ALL APPLICABLE CODES REFERENCED IN BID SPECIFICATIONS AND SHALL BE CONSISTENT WITH MANUFACTURER'S SPECIFICATIONS. ALL WIRING AND CONDUIT REQUIREMENTS SHALL BE VERIFIED WITH THE MANUFACTURER.
- UPON COMPLETION OF THE ALL WORK, THE CONTRACTOR SHALL SUBMIT 'AS-BUILT' DRAWINGS (IN ELECTRONIC FORMAT) OF MODIFIED EXISTING FIRE ALARM SYSTEM TO THE CM.
- THE ELECTRICAL AND FIRE ALARM CONTRACTORS SHALL FILE FOR ALL WORK PERMITS AND PAY ALL FILING FEES WITH THE AHJ. ALL EXPEDITING SERVICES SHALL BE PROVIDED BY THE ELECTRICAL CONTRACTOR.
- THE GENERAL CONTRACTOR & CONSTRUCTION MANAGER SHALL BE RESPONSIBLE FOR ALL PATCHING AND FINISHING OF SURFACES DAMAGED BY INSTALLATION OF NEW EQUIPMENT AND REMOVAL OF EXISTING FIRE ALARM EQUIPMENT. ALL FLOOR AND WALL PENETRATIONS SHALL BE FILED WITH AN APPROVED FIRE STOPPING MATERIAL. THE CONTRACTORS SHALL COORDINATE ALL PATCHING, FINISHING AND LOCATION OF THE NEW AND EXISTING EQUIPMENT WITH THE CM. THE CM SHALL SCHEDULE AND APPROVE ALL WORK.
- UPON COMPLETION OF THIS INSTALLATION AND APPROVAL BY THE AHJ, THE FIRE ALARM CONTRACTOR SHALL WARRANTY THE ENTIRE INSTALLATION FOR A PERIOD OF FIVE (5) YEARS. WARRANTY SHALL INCLUDE ALL PARTS & LABOR.
- UPON COMPLETION OF THE ENTIRE SYSTEM INSTALLATION AND APPROVAL BY THE AHJ, THE ELECTRICAL CONTRACTOR SHALL PROVIDE THE OWNER WITH 'AS-BUILT' DRAWINGS, DEPICTING THE EXACT INSTALLATION. DRAWINGS SHALL BE SUBMITTED IN ELECTRONIC FORMAT FOR AUTOCAD MEP.
- THE ELECTRICAL AND FIRE ALARM CONTRACTORS SHALL PROVIDE ADEQUATE PERSONNEL FOR ALL PRE-TESTING AND AHJ INSPECTIONS; INCLUDING REPRESENTATION FROM THE FIRE ALARM SYSTEM MANUFACTURER.
- ALL WORK SHALL CONFORM TO ALL APPLICABLE CODES AND STANDARDS AS REQUIRED BY THE AHJ. ALL MANUFACTURER'S SPECIFICATIONS SHALL ALSO APPLY.
- UPON REVIEW OF CONSTRUCTION DOCUMENTS AND PRIOR TO THE SUBMISSION OF PROPOSALS, THE CONTRACTORS SHALL INFORM THE CM OF ANY DISCREPANCIES OR REQUEST CLARIFICATIONS, IF NECESSARY, CONCERNING THE INTENT OF THE PLANS AND SPECIFICATIONS.

**SEQUENCE OF OPERATIONS MATRIX**

SYSTEM FUNCTIONS	SYSTEM DEVICES							DESCRIPTION OF OPERATION
	MANUAL INITIATION AT FACP	SMOKE /HEAT DETECTOR, AREA	SMOKE DETECTOR, ELEVATOR LANDING	SMOKE DETECTOR, ELEVATOR MACHINE ROOM	SMOKE DETECTOR, TOP OF ELEVATOR HOISTWAY	HEAT DETECTOR, ELEVATOR MACHINE ROOM	HEAT DETECTOR, ELEVATOR PIT AND TOP OF HOISTWAY	
ALARM SIGNALING, AUTOMATIC		X	X	X	X	X	X	AUDIBLE SIGNAL AND VISIBLE ANNUNCIATION OF SIGNAL TYPE AND LOCATION AT FACP AND REMOTE ANNUNCIATORS. ALL FLASHING LIGHTS SHALL ACTIVATE AND ALL FIRE ALARM HORNS SHALL SOUND AN ALARM TONE ON ALL FLOORS.
ALARM SIGNALING, MANUAL CONTROL FROM MAIN FACP	X							MANUAL INITIATION OF CONTROLS FOR STANDARD ALARM SIGNALS (AUDIBLE, VISIBLE) IN SELECTED ZONES OR ALL ZONES.
TRANSMIT TO AN APPROVED CENTRAL STATION (SUPERVISING STATION), ALARM		X	X	X	X	X	X	TRANSMIT THE APPROPRIATE ALARM SIGNALS (MANUAL, AUTOMATIC, WATER FLOW) TO CENTRAL STATION.
DOORS, FIRE / SMOKE BARRIER OPENING PROTECTIVES HELD OPEN	X		X	X	X			RELEASE MAGNETICALLY HELD DOORS AND ACTIVATE AUTOMATIC SHUTTERS UTILIZED AS PART OF FIRE / SMOKE BARRIER ASSEMBLIES.
DOORS / GATES, ELECTRICALLY LOCKED	X		X	X	X			UNLOCK ALL ELECTRICALLY LOCKED DOORS / GATES IN THE INGRESS AND EGRESS PATH (WHEN PERMITTED TO BE LOCKED)
ELEVATOR, EMERGENCY RECALL			X	X	X			RECALL ALL ELEVATORS SERVING ALARM FLOOR TO THE DESIGNATED LEVEL.
ELEVATOR, SHUNT TRIP		X	X			X	X	ACTIVATE SHUNT TRIP FOR ELEVATOR ASSOCIATED WITH THE HOISTWAY / MACHINE ROOM WITH INITIATED HEAT DETECTOR. SHUNT TRIP SHALL BE ON A DELAY TO ALLOW FOR PHASE I RECALL. WATERFLOW SHALL INITIATE SHUNT TRIP WITHOUT DELAY
VENTILATION FANS SMOKE DAMPERS	X							SHUT DOWN FANS OVER 2000 CFM. CLOSE SMOKE DAMPERS UPON ACTIVATION OF ASSOCIATED DUCT DETECTOR OR SHUT DOWN OF ASSOCIATED VENTILATION FAN.



REV	DATE	DESCRIPTION
	07/14/2016	100% SD
	08/04/2016	100% DD
	09/13/2016	50% CD
	11/08/2016	90% CD
	01/17/2017	PLAN CHECK #1
	03/09/2017	PERMIT SET
	06/14/2017	100% CD / CONFORMED SET

**EAST COUNTY COURTHOUSE ELEVATOR MODERNIZATION**  
250 E Main St, El Cajon, CA 92020




**FIRE ALARM GENERAL NOTES**

SYMBOLS LEGEND	
EVERYTHING IS EXISTING, UNLESS NOTED AS (N) FOR NEW.	
FIRE ALARM CONDUIT	
	CONDUIT (3/4" MIN.)
	CABLE TYPE LABEL
	CLASS A RETURN
	END OF LINE RESISTOR
FIRE ALARM PANELS	
	FIRE ALARM CONTROL PANEL
	TERMINAL BOX W/ TERMINAL STRIPS
FIRE ALARM INITIATING DEVICES	
	ADDRESSABLE AREA HEAT DETECTOR W/ REMOTE LED
	ADDRESSABLE AREA SMOKE DETECTOR W/ REMOTE LED
	ADDRESSABLE AREA SMOKE DETECTOR W/ REMOTE LED FOR PHASE-1 ELEVATOR RECALL
	ADDRESSABLE DUCT MOUNTED SMOKE DETECTOR W/ REMOTE LED & TEST SWITCH (X = S: DENOTES SUPPLY; X = R: DENOTES RETURN)
	ADDRESSABLE INTERFACE MONITOR MODULE
	ADDRESSABLE INTERFACE CONTROL MODULE
	AUXILIARY INTERFACE CONTROL RELAY

FIRE ALARM CABLE TYPE LEGEND					
ID	DESCRIPTION	TYPE	ID	DESCRIPTION	TYPE
A	ADDRESSABLE CIRCUIT	#16 T.S.P.	M	-	-
B	HORN CIRCUIT	#14 PR	N	-	-
C	STROBE CIRCUIT	#14 PR	P	-	-
D	CONTROL CIRCUIT	#14 PR	R	-	-
E	MONITORING CIRCUIT	#16 PR	S	-	-
F	24VDC POWER CIRCUIT	#14 PR	T	-	-
G	GROUND CONDUCTOR	#10 COND	U	-	-
H	120VAC POWER CIRCUIT	2 #10 PR	W	-	-
J	-	-	X	-	-
K	-	-	Y	-	-
L	-	-	Z	-	-

THE CABLE TYPES LISTED REPRESENT BASIC FUNCTIONAL REQUIREMENTS OF A STANDARD FIRE ALARM SYSTEM. MANUFACTURERS REQUIRING VARIATIONS OF THE CABLE TYPES LISTED SHALL MAKE SUBSTITUTIONS ACCORDINGLY.



FIRE ALARM RISER DIAGRAM

**CAVAGNERO**  
 ARCHITECTS  
 1000 S. GARDEN ST. SUITE 200  
 ANAHEIM, CA 92805  
 TEL: 714.771.1111  
 FAX: 714.771.1112

**SYSKA HENNESSY**  
 group  
 A member company of SH Group, Inc.  
 Syska Hennessy Group, Inc.  
 800 Corporate Pointe  
 Suite 200  
 Culver City, CA 90230  
 Tel: 310.312.0200  
 Fax: 310.665.0172  
 www.syska.com


REV	DATE	DESCRIPTION
07/14/2016	100% SD	
08/04/2016	100% DD	
09/13/2016	50% CD	
11/08/2016	90% CD	
01/17/2017	PLAN CHECK #1	
03/09/2017	PERMIT SET	
06/14/2017	100% CD / CONFORMED SET	

EAST COUNTY COURTHOUSE  
 ELEVATOR MODERNIZATION  
 250 E Main St, El Cajon, CA 92020



FIRE ALARM RISER DIAGRAM

E.005



**1** GROUND FLOOR POWER & LIGHTING PLAN  
 E2.00 SCALE: 1/8" = 1'-0"

- KEYNOTES:**
- ① DEMOLISH EXISTING PIT FIXTURE AND SWITCH. EXISTING CIRCUIT AND SWITCH LEG TO BE REUSED. PROVIDE LITHONIA #OLVTWM FIXTURE AND CONNECT TO EXISTING CIRCUIT AND SWITCH LEG. PROVIDE NEW NEMA 4 MANUAL ON/OFF SWITCH AND CONNECT TO EXISTING SWITCH LEG.
  - ② DEMOLISH EXISTING RECEPTACLE AND REPLACE WITH GFCI, WEATHERPROOF RECEPTACLE. CONNECT EXISTING CIRCUIT TO NEW DEVICE.
  - ③ PROVIDE SMOKE DETECTOR AT ELEVATOR ENTRANCE ON EACH FLOOR



REV	DATE	DESCRIPTION
	07/14/2016	100% SD
	08/04/2016	100% DD
	09/13/2016	50% CD
	11/08/2016	90% CD
	01/17/2017	PLAN CHECK #1
	03/09/2017	PERMIT SET
	06/14/2017	100% CD / CONFORMED SET

**EAST COUNTY COURTHOUSE**  
**ELEVATOR MODERNIZATION**  
 250 E Main St, El Cajon, CA 92020



**GROUND FLOOR ELECTRICAL PLAN**

**E2.00**



**1** FIFTH FLOOR POWER & LIGHTING PLAN  
 E2.05 SCALE: 1/8" = 1'-0"

KEYNOTES:  
 (1) PROVIDE SMOKE DETECTOR AT ELEVATOR ENTRANCE.



**SYSKA HENNESSY**  
 group  
 A member company of SH Group, Inc.  
 Syska Hennessy Group, Inc.  
 800 Corporate Pointe  
 Suite 200  
 Culver City, CA 90230  
 Tel: 310.312.0200  
 Fax: 310.665.0172  
 www.syska.com

REV	DATE	DESCRIPTION
	07/14/2016	100% SD
	08/04/2016	100% DD
	09/13/2016	50% CD
	11/08/2016	90% CD
	01/17/2017	PLAN CHECK #1
	03/09/2017	PERMIT SET
	06/14/2017	100% CD / CONFORMED SET

**EAST COUNTY COURTHOUSE**  
**ELEVATOR MODERNIZATION**  
 250 E Main St, El Cajon, CA 92020



**FIFTH FLOOR ELECTRICAL PLAN**

**E2.05**


REV	DATE	DESCRIPTION
	07/14/2016	100% SD
	08/04/2016	100% DD
	09/13/2016	50% CD
	11/08/2016	90% CD
	01/17/2017	PLAN CHECK #1
	03/09/2017	PERMIT SET
	06/14/2017	100% CD / CONFORMED SET

**EAST COUNTY COURTHOUSE  
 ELEVATOR MODERNIZATION**  
 250 E Main St, El Cajon, CA 92020



**SIXTH FLOOR ELECTRICAL PLAN**


**E2.06**



**1** SIXTH FLOOR POWER PLAN  
 E2.06 SCALE: 1/8" = 1'-0"

**POWER KEYNOTES:**

- ① PROVIDE SMOKE DETECTOR AT ELEVATOR ENTRANCE.
- ② PROVIDE JUNCTION BOX FOR LIFE SAFETY TERMINAL BOX.
- ③ FUSED DISCONNECT FOR ELEVATOR MOTOR. SEE SINGLELINE DIAGRAM FOR CIRCUITING INFORMATION AND SIZE. COORDINATE EXACT LOCATION WITH ELEVATOR VENDOR.
- ④ PROVIDE JUNCTION BOX FOR SHERIFF COMMUNICATION SYSTEM. CONTRACTOR TO PROVIDE FROM SHERIFF'S STATION TO JUNCTION BOX.
- ⑤ PROVIDE LOCKABLE, 120V, 20A, 1P ENCLOSED CIRCUIT BREAKER FOR ELEVATOR CONTROLLER.
- ⑥ DEMOLISH EXISTING CAB LIGHT SWITCH. PROVIDE MOTOR RATED SWITCH WITH THERMAL PROTECTION AND CONNECT TO EXISTING CIRCUIT.
- ⑦ PROVIDE NEW GFCI RECEPTACLE. PROVIDE 2#12+1#12G, .3/4" C. TO SPARE 20A/1P BREAKER IN PANEL 6PE.
- ⑧ PROVIDE JUNCTION BOX FOR EMERGENCY TWO-WAY COMMUNICATION.
- ⑨ POWER FOR INDOOR UNIT SUPPLIED BY OUTDOOR UNIT, HP-6. PROVIDE MOTOR RATED SWITCH. COORDINATE WITH MANUFACTURER FOR EXACT SIZE. PROVIDE 2#12+1#12G, .3/4" C. FROM SWITCH TO OUTDOOR UNIT.
- ⑩ EXISTING DISTRIBUTION BOARD TO BE DEMOLISHED AND REPLACED WITH PULLBOX. EXTEND EXISTING INCOMING FEEDER TO NEW LOCATION OF NEW DISTRIBUTION PANELBOARD.



**2** SIXTH FLOOR LIGHTING PLAN  
 E2.06 SCALE: 1/8" = 1'-0"

**LIGHTING KEYNOTES:**

- ① DEMOLISH EXISTING FIXTURES AND SWITCH IN ROOM. EXISTING CIRCUIT AND SWITCH LEG TO BE REUSED. PROVIDE LITHONIA #SBL4-LP840 FIXTURE AND CONNECT TO EXISTING CIRCUIT AND SWITCH LEG. PROVIDE NEW MANUAL ON/OFF SWITCH AND CONNECT TO EXISTING SWITCH LEG. FIXTURES TO BE PENDANT MOUNTED WITH CHAIN HANGARS.


REV	DATE	DESCRIPTION
	07/14/2016	100% SD
	08/04/2016	100% DD
	09/13/2016	50% CD
	11/08/2016	90% CD
	01/17/2017	PLAN CHECK #1
	03/09/2017	PERMIT SET
	06/14/2017	100% CD / CONFORMED SET

**EAST COUNTY COURTHOUSE**  
**ELEVATOR MODERNIZATION**  
250 E Main St, El Cajon, CA 92020



**NINTH FLOOR ELECTRICAL PLAN**

**E2.09**



**1** NINTH FLOOR POWER PLAN  
E2.09 SCALE: 1/8" = 1'-0"

**2** NINTH FLOOR LIGHTING PLAN  
E2.09 SCALE: 1/8" = 1'-0"

**POWER KEYNOTES:**

- ① PROVIDE SMOKE DETECTOR AT ELEVATOR ENTRANCE.
- ② PROVIDE JUNCTION BOX FOR LIFE SAFETY TERMINAL BOX.
- ③ FUSED DISCONNECT FOR ELEVATOR MOTOR. SEE SINGLELINE DIAGRAM FOR CIRCUITING INFORMATION AND SIZE. COORDINATE EXACT LOCATION WITH ELEVATOR VENDOR.
- ④ PROVIDE JUNCTION BOX FOR SHERIFF COMMUNICATION SYSTEM. CONTRACTOR TO PROVIDE FROM SHERIFF'S STATION TO JUNCTION BOX.
- ⑤ PROVIDE LOCKABLE, 120V, 20A, 1P ENCLOSED CIRCUIT BREAKER FOR ELEVATOR CONTROLLER.
- ⑥ DEMOLISH EXISTING CAB LIGHT SWITCH. PROVIDE MOTOR RATED SWITCH WITH THERMAL PROTECTION AND CONNECT TO EXISTING CIRCUIT.
- ⑦ PROVIDE NEW GFCI RECEPTACLE. PROVIDE 2#12+1#12G, 3/4"C. TO SPARE 20A/1P BREAKER IN PANEL 7PE.
- ⑧ PROVIDE JUNCTION BOX FOR EMERGENCY TWO-WAY COMMUNICATION.
- ⑨ POWER FOR INDOOR UNIT SUPPLIED BY OUTDOOR UNIT, HP-9. PROVIDE MOTOR RATED SWITCH. COORDINATE WITH MANUFACTURER FOR EXACT SIZE. PROVIDE 2#12+1#12G, 3/4"C. FROM SWITCH TO OUTDOOR UNIT.
- ⑩ EXISTING DISTRIBUTION BOARD TO BE DEMOLISHED AND REPLACED WITH PULLBOX. EXTEND EXISTING INCOMING FEEDER TO NEW LOCATION OF NEW DISTRIBUTION PANELBOARD.
- ⑪ PROVIDE NEMA 3R FUSIBLE DISCONNECT. COORDINATE WITH MANUFACTURER FOR EXACT SIZE.

**LIGHTING KEYNOTES:**

- ① DEMOLISH EXISTING FIXTURES AND SWITCH IN ROOM. EXISTING CIRCUIT AND SWITCH LEG TO BE REUSED. PROVIDE LITHONIA #SBL4-LP840 FIXTURE AND CONNECT TO EXISTING CIRCUIT AND SWITCH LEG. PROVIDE NEW MANUAL ON/OFF SWITCH AND CONNECT TO EXISTING SWITCH LEG. FIXTURES TO BE PENDANT MOUNTED WITH CHAIN HANGARS.


REV	DATE	DESCRIPTION
	07/14/2016	100% SD
	08/04/2016	100% DD
	09/13/2016	50% CD
	11/08/2016	90% CD
	01/17/2017	PLAN CHECK #1
	03/09/2017	PERMIT SET
	06/14/2017	100% CD / CONFORMED SET

**EAST COUNTY COURTHOUSE**  
**ELEVATOR MODERNIZATION**  
 250 E Main St, El Cajon, CA 92020



**TENTH FLOOR ELECTRICAL PLAN**


**E2.10**



**1** TENTH FLOOR POWER PLAN  
 E2.10 SCALE: 1/8" = 1'-0"

**POWER KEYNOTES:**






- ① PROVIDE SMOKE DETECTOR AT ELEVATOR ENTRANCE.
- ② PROVIDE JUNCTION BOX FOR LIFE SAFETY TERMINAL BOX.
- ③ FUSED DISCONNECT FOR ELEVATOR MOTOR. SEE SINGLELINE DIAGRAM FOR CIRCUITING INFORMATION AND SIZE. COORDINATE EXACT LOCATION WITH ELEVATOR VENDOR.
- ④ PROVIDE JUNCTION BOX FOR SHERIFF COMMUNICATION SYSTEM. CONTRACTOR TO PROVIDE FROM SHERIFF'S STATION TO JUNCTION BOX.
- ⑤ PROVIDE LOCKABLE, 120V, 20A, 1P ENCLOSED CIRCUIT BREAKER FOR ELEVATOR CONTROLLER.
- ⑥ DEMOLISH EXISTING CAB LIGHT SWITCH. PROVIDE MOTOR RATED SWITCH WITH THERMAL PROTECTION AND CONNECT TO EXISTING CIRCUIT.
- ⑦ PROVIDE NEW GFCI RECEPTACLE. PROVIDE 2#12+1#12G, 3/4" C. TO SPARE 20A/1P BREAKER IN PANEL 8PE.
- ⑧ PROVIDE JUNCTION BOX FOR EMERGENCY TWO-WAY COMMUNICATION.
- ⑨ PROVIDE FUSIBLE DISCONNECT. COORDINATE WITH MANUFACTURER FOR EXACT SIZE. PROVIDE 3/4" C.O. FROM INDOOR UNIT TO OUTDOOR UNIT, HP-10 FOR CONTROL WIRING.
- ⑩ EXISTING DISTRIBUTION BOARD TO BE DEMOLISHED AND REPLACED WITH PULLBOX. EXTEND EXISTING INCOMING FEEDER TO NEW LOCATION OF NEW DISTRIBUTION PANELBOARD.
- ⑪ PROVIDE NEMA 3R FUSIBLE DISCONNECT. COORDINATE WITH MANUFACTURER FOR EXACT SIZE.



**2** SIXTH FLOOR LIGHTING PLAN  
 E2.10 SCALE: 1/8" = 1'-0"

**LIGHTING KEYNOTES:**

- ① DEMOLISH EXISTING FIXTURES AND SWITCH IN ROOM. EXISTING CIRCUIT AND SWITCH LEG TO BE REUSED. PROVIDE LITHONIA #SBL4-LP840 FIXTURE AND CONNECT TO EXISTING CIRCUIT AND SWITCH LEG. PROVIDE NEW MANUAL ON/OFF SWITCH AND CONNECT TO EXISTING SWITCH LEG. FIXTURES TO BE PENDANT MOUNTED WITH CHAIN HANGARS.



REV	DATE	DESCRIPTION
	07/14/2016	100% SD
	08/04/2016	100% DD
	09/13/2016	50% CD
	11/08/2016	90% CD
	01/17/2017	PLAN CHECK #1
	03/09/2017	PERMIT SET
	06/14/2017	100% CD / CONFORMED SET

EAST COUNTY COURTHOUSE  
ELEVATOR MODERNIZATION  
250 E Main St, El Cajon, CA 92020



ELECTRICAL DETAILS





**ENERGY CONSERVATION NOTES**

MANDATORY MEASURES (§110-119 AND §120-129) APPLY TO ALL SYSTEMS, WHETHER THE DESIGNER CHOOSES THE PRESCRIPTIVE OR PERFORMANCE APPROACH TO COMPLIANCE. MANDATORY MEASURES INCLUDE:

- CERTIFICATION OF EQUIPMENT EFFICIENCY (§110 AND §111).
- HVAC AND SERVICE WATER HEATING EQUIPMENT EFFICIENCIES (§112 AND §113).
- SERVICE WATER HEATING AND POOL HEATING MEASURES (§113 AND §114).
- VENTILATION REQUIREMENTS (§121).
- DEMAND CONTROLLED VENTILATION §121(C).
- THERMOSTATS, SHUT-OFF CONTROL AND NIGHT SETBACK/SETUP (§122).
- AREA ISOLATION (§122).
- PIPE INSULATION (§123).
- DUCT CONSTRUCTION AND INSULATION (§124).
- ACCEPTANCE TESTS (§125 AND REFERENCE NONRESIDENTIAL APPENDIX NA7).

**LIFE SAFETY NOTES**

2 FIRE ALARM SYSTEM DESIGN UNDER ELECTRICAL DRAWINGS AND DIV. 26 / DIV. 28 SPECIFICATIONS CONTRACTOR SHALL EXAM RECORD DRAWINGS TO LOCATE AND TEST ALL EXISTING FIRE DAMPERS AND REPORT RESULTS TO OWNER'S REPRESENTATIVE. ANY FIRE DAMPERS THAT ARE FOUND TO BE NON-OPERATIONAL SHALL BE REPLACED IN KIND. INSTALL FIRE DAMPER OR COMBINATION FIRE/SMOKE DAMPER ON ALL DUCTS PENETRATING FIRE RATED ENCLOSURES AND PARTITIONS, AND RATED CEILINGS OF HORIZONTAL EXITS. THE CONTRACTOR SHALL INTERLOCK ALL COMBINATION FIRE/SMOKE DAMPERS WITH LISTED AREA TYPE SMOKE DETECTORS IN THE BUILDING FIRE LIFE SAFETY SYSTEM. VERIFY WITH LIFE SAFETY SYSTEM CONTRACTOR. SEE FIRE ALARM SPECIFICATION AND SMOKE CONTROL NOTES FOR ADDITIONAL INFORMATION.

**MECHANICAL GENERAL NOTES**

1. WHERE THERE IS A DISCREPANCY BETWEEN THE DRAWINGS AND SPECIFICATIONS, NOTIFY THE ENGINEER PRIOR TO BID. FOR BIDDING PURPOSES THE MORE STRINGENT SHALL APPLY.
2. THE CONTRACTOR SHALL EXAMINE THE COMPLETE SET OF CONTRACT DOCUMENTS FOR ALL TRADES, AS ISSUED BY THE ARCHITECT AND REVIEW DIMENSIONS, SPACE REQUIREMENTS AND POINT OF CONNECTIONS TO ALL EQUIPMENT. MAKE ANY MINOR ADJUSTMENTS NECESSARY TO AVOID CONFLICTS WITH THE BUILDING STRUCTURE AND THE WORK OF OTHER TRADES.
3. UNLESS INSTRUCTED OTHERWISE, THE CONTRACTOR SHALL OBTAIN AND PAY FOR ALL PERMITS, LICENSES, AND FEES REQUIRED FOR INSTALLATION OF THE MECHANICAL WORK. FURNISH FINAL CERTIFICATE OF INSPECTION OR WRITTEN EVIDENCE OF ACCEPTANCE BY INSPECTION AUTHORITIES FOR ALL WORK INSTALLED.
4. REFER TO COMPLETE DRAWING PACKAGE FOR EXTENT OF CONSTRUCTION, AND EXACT LOCATION OF FIXTURES, EQUIPMENT, DEVICES, ETC.
5. CONTRACTOR SHALL COORDINATE WITH ALL TRADES TO ENSURE AN UNDERSTANDING OF THE COMPLETE SCOPE OF PROJECT PRIOR TO START OF WORK.
6. ALL EQUIPMENT & MATERIALS SHALL MATCH DESIGN SPECIFICATIONS AND MANUFACTURER'S RECOMMENDED INSTALLATION INSTRUCTIONS.
7. LOCATION OF DUCTWORK IS APPROXIMATE. ALL DRAWINGS AND LAYOUT ARE DIAGRAMMATIC TO SHOW DESIGN INTENT ONLY. CONTRACTOR TO COORDINATE ALL DUCTWORK AND PIPING WITH ALL OTHER WORK IF FIELD CONDITIONS DIFFER SIGNIFICANTLY FROM THOSE SHOWN ON THE DRAWINGS AND AFFECT WORK, INFORM ARCHITECT IMMEDIATELY BEFORE PROCEEDING WITH THAT AREA.
8. INSTALL FIRE DAMPER OR COMBINATION FIRE/SMOKE DAMPER ON ALL DUCTS PENETRATING FIRE RATED ENCLOSURES AND PARTITIONS, AND RATED CEILINGS OF HORIZONTAL EXITS. THE CONTRACTOR SHALL INTERLOCK ALL COMBINATION FIRE/SMOKE DAMPERS WITH LISTED AREA TYPE SMOKE DETECTORS IN THE BUILDING FIRE LIFE SAFETY SYSTEM. VERIFY WITH LIFE SAFETY SYSTEM CONTRACTOR. SEE FIRE ALARM SPECIFICATION AND SMOKE CONTROL NOTES FOR ADDITIONAL INFORMATION.
9. AIR HANDLING UNITS AND FAN COIL UNITS SHALL BE PROVIDED WITH DUCT SMOKE DETECTORS AT THE UNITS OUTLET WHEN THE UNITS CAPACITY EQUALS 2000 CFM OR GREATER.
10. A MINIMUM OF 36" CLEAR WORKING SPACE, NOT LESS THAN 30" WIDE, SHALL BE MAINTAINED IN FRONT OF ALL SWITCHES, OVERCURRENT DEVICES AND ELECTRIC CONTROL COMPONENTS. THE WORKING SPACE SHALL BE CLEAR AND EXTEND FROM THE GRADE, FLOOR, OR PLATFORM TO MINIMUM OF 6'-8" FT. WHERE THE ELECTRICAL EQUIPMENT EXCEEDS 6-1/2 FT IN HEIGHT, THE MINIMUM HEADROOM SHALL NOT BE LESS THAN THE HEIGHT OF THE EQUIPMENT
11. A MINIMUM OF 24" CLEAR WORKING SPACE SHALL BE PROVIDED IN FRONT OF THE ACCESS PANELS.
12. THE SMOKE DETECTORS LOCATED AT AIR MOVING EQUIPMENT SHALL SHUT DOWN ALL AIR HANDLING EQUIPMENT VIA THE LIFE SAFETY SYSTEM. WHEN SMOKE IS DETECTED AT EQUIPMENT, ALL OTHER AIR MOVING EQUIPMENT LOCATED IN OR CONNECTED TO COMMON PLENUM OR SMOKE ZONE SHALL SHUT DOWN.
13. ALL ELECTRICAL CONTROLS FOR THE SMOKE CONTROL SHALL BE RATED FOR SUCH USE.
14. PROVIDE ACCESS PANELS (MATCH WALL OR CEILING RATING) IN ALL WALLS OR CEILINGS WHERE ACCESS TO DAMPERS, CONTROLS, ETC ARE REQUIRED BY CODE. COORDINATE LOCATIONS WITH ARCHITECT.
15. CONTRACTOR SHALL NOTE THE CRITICAL SPACE AVAILABLE ABOVE CEILINGS. PROVIDE TRANSITION PIECES AT CROSSOVERS, UNDER BEAMS, OVER/UNDER PIPES, AS REQUIRED TO ACCOMMODATE DUCTS WITHIN SPACE AVAILABLE, PROVIDING EQUIVALENT DUCT SIZE TO THE DIAMETER SHOWN. COORDINATE CLOSELY WITH OTHER TRADES TO REDUCE NECESSITY OF TRANSITIONS TO A MINIMUM. NO ADDITIONAL COSTS WILL BE PAID FOR ANY REQUIRED TRANSITIONS OR OTHER SPECIAL CHANGE SHAPE PIECES. ALL DUCTWORK SHALL BE SUPPORTED AND SEISMICALLY RESTRAINED PER THE CALIFORNIA BUILDING CODES AND SMACNA STANDARD.
16. THERE SHALL BE NO PIPING AND/OR DUCTWORK RUN THROUGH ELECTRICAL ROOMS UNLESS THAT DUCTWORK AND/OR PIPING IS SERVING THAT ELECTRICAL SPACE.
17. ALL FLEXIBLE DUCT CONNECTIONS TO AIR DISTRIBUTION DEVICES TO BE MIN. 5'-0" ACOUSTICAL FLEX DUCT PER SPECIFICATIONS.
18. NOT ALL SYMBOLS, NOTES, DETAILS AND EQUIPMENT IN SCHEDULES ON GENERAL SHEETS WILL APPLY TO EACH BUILDING. THEY ARE TO COVER ALL BUILDINGS AND WILL APPLY BASED ON SCOPE IN BUILDING.
19. LOCATE EXISTING REINFORCING STEEL UTILIZING ANY SUITABLE METAL DETECTION SYSTEM. DO NOT CUT ANY EXISTING STEEL REINFORCEMENT. SHIFT ANCHOR OR CORE TO MISS THE REBAR.
20. BOLTS MUST BE INSTALLED TO AVOID DAMAGING EXISTING STEEL REINFORCEMENT. IN CASE OF CONFLICT, ADJUST BOLT LOCATION, ALLOWING FOR 1" CONCRETE COVER BETWEEN REBAR AND BOLT.
21. PROVIDE TRANSFER DUCTS AS NECESSARY ABOVE CEILING FOR RETURN AIR PATH TO AIR HANDLING EQUIPMENT SERVING THAT SPACE. REFER TO DETAILS FOR TRANSFER DUCT SIZES.
22. ALL WORK SHALL COMPLY WITH THE STATE OF CALIFORNIA BUILDING CODE, TITLE 24 ENERGY CODE, CALGREEN, AND ALL OTHER GOVERNING CODES AND ORDINANCES.
23. COMBUSTIBLES WITHIN THE PLENUM SPACE MUST COMPLY WITH CALIFORNIA CODE FLAME-SPREAD INDEX OF NOT MORE THAN 25 AND A SMOKE-DEVELOPED RATING OF NOT MORE THAN 50.



REV	DATE	DESCRIPTION
	07/14/2016	100% SD
	08/04/2016	100% DD
	09/13/2016	50% CD
	11/08/2016	90% CD
	01/17/2017	PLAN CHECK #1
	03/09/2017	PERMIT SET
	08/14/2017	100% CD / CONFORMED SET

**EAST COUNTY COURTHOUSE  
ELEVATOR MODERNIZATION**  
250 E Main St, El Cajon, CA 92020



**MECHANICAL GENERAL NOTES**

**M0.02**

# MECHANICAL SPECIFICATIONS (AS APPLICABLE)

DIVISION NO. 23 SECTION 23000  
MECHANICAL SPECIFICATION

PART 1 GENERAL  
1.01 GENERAL PROVISIONS

- A. GENERAL REQUIREMENTS:**
1. RELATED DOCUMENTS: ENGINEERING SPECIFICATIONS, APPLIANCE AND FIXTURE SPECIFICATION PACKAGE, GENERAL, SPECIAL AND SUPPLEMENTARY CONDITIONS, SHALL FORM A PART OF THESE SPECIFICATIONS.
  2. SCOPE OF WORK: PROVIDE ALL REQUIRED LABOR, MATERIALS, EQUIPMENT AND CONTRACTOR'S SERVICES NECESSARY FOR COMPETE AND SAFE INSTALLATION OF HEATING, VENTILATING, AIR CONDITIONING (HVAC) AND PLUMBING WORK IN CONFORMITY WITH REQUIREMENTS OF ALL AUTHORITIES HAVING JURISDICTION; AS INDICATED ON DRAWINGS AND/OR HERE IN SPECIFIED OR DESCRIBED.
  3. SITE CLEANLINESS: KEEP SITE FREE FROM THIS SECTION'S SURPLUS MATERIAL, TOOLS AND RUBBISH AT ALL TIMES DURING CONSTRUCTION PERIODS AND, UPON COMPLETION, LEAVE SITE IN CLEAN CONDITION.
  4. SITE SECURITY: PROTECT THIS SECTION'S MATERIALS AND EQUIPMENT FROM ALL DAMAGE DUE TO FIRE, THEFT, VANDALISM, WEATHER, ETC.
  5. DAMAGE TO OTHER WORK: REPAIR ANY DAMAGED FIREPROOFING CAUSED BY THIS SECTION TO INTEGRITY OF ORIGINAL CONSTRUCTION.
  6. DAMAGE TO FIREPROOFING: REPAIR ANY DAMAGED FIREPROOFING CAUSED BY THIS SECTION TO INTEGRITY OF ORIGINAL CONSTRUCTION.
  7. SITE SAFETY: CONTRACTOR COVENANTS AND AGREES THAT HE AND HIS SUBCONTRACTORS AND HIS AND THEIR AGENTS, SERVANTS AND EMPLOYEES WILL PROVIDE AND MAINTAIN A SAFE PLACE TO WORK AND THAT HE AND THEY WILL COMPLY WITH ALL LAWS AND REGULATIONS OF ANY GOVERNMENTAL AUTHORITY HAVING JURISDICTION THEREOF, AND CONTRACTOR AGREES TO INDEMNIFY, DEFEND AND HOLD HARMLESS, ENGINEER, OWNER AND ARCHITECT FROM AND AGAINST ANY LIABILITY, LOSS, DAMAGE OR EXPENSE, INCLUDING ATTORNEY'S FEES, ARISING FROM A FAILURE OR ALLEGED FAILURE ON THE PART OF CONTRACTOR, THIS SUBCONTRACTORS AND HIS AND THEIR AGENTS, SERVANTS AND EMPLOYEES TO PROVIDE AND MAINTAIN A SAFE PLACE TO WORK OR TO COMPLY WITH ALL LAWS AND REGULATIONS OF ANY GOVERNMENTAL AUTHORITY HAVING JURISDICTION THEREOF.
  8. VERIFICATION OF EXISTING: BEFORE SUBMITTING BID, CONTRACTOR SHALL VISIT THE SITE AND BECOME THOROUGHLY FAMILIAR WITH ACTUAL EXISTING CONDITIONS AND OF THE PRESENT INSTALLATIONS TO WHICH CONNECTIONS MUST BE MADE OR WHICH MUST BE CHANGED OR ALTERED. THE INTENT OF THE WORK IS SHOWN ON THE DRAWINGS AND DESCRIBED HEREIN, AND NO CONSIDERATION WILL BE GRANTED BY REASON OF LACK OF FAMILIARITY ON THE PART OF THE CONTRACTOR WITH ACTUAL PHYSICAL CONDITIONS, REQUIREMENTS, AND PRACTICES AT THE SITE.
  9. REQUIREMENTS OF OTHER SECTIONS: CAREFULLY CHECK THE DOCUMENTS OF OTHER SECTIONS TO ASCERTAIN THE REQUIREMENTS OF ANY INTERFACING MATERIALS OR EQUIPMENT BEING FURNISHED AND/OR INSTALLED BY THAT SECTION WHICH RELATE TO THIS SECTION, AND PROVIDE THE PROPER INSTALLATION AND/OR CONNECTION.
  10. INFORMATION TRANSFER: TRANSMIT ALL INFORMATION REQUIRED FOR WORK BEING PERFORMED BY OTHER SECTIONS IN AMPLE TIME FOR THE PROPER INSTALLATION AND CONNECTION AND FOR THE PROVISION OF ALL OPENINGS REQUIRED IN FLOORS AND WALLS.
  11. HOLES AND STRUCTURE: FIELD DRILLING AND CUTTING OF HOLES IN BUILDING STRUCTURE REQUIRED FOR WORK UNDER THIS SECTION SHALL BE COORDINATED THROUGH THE GENERAL CONTRACTOR AND APPROVED BY OWNER AND BUILDING STRUCTURAL ENGINEER. ALL SUCH COORDINATION, DRILLING, CUTTING AND REINFORCING COSTS SHALL BE BORNE BY THIS CONTRACTOR.
  12. SLEEVES: FURNISH AND SET ALL SLEEVES FOR THE PASSAGE OF CONDUIT THROUGH WALLS, ROOF AND FLOORS AND ELSEWHERE AS WILL BE REQUIRED FOR THE PROPER PROTECTION OF EACH CONDUIT PASSING THROUGH BUILDING SURFACES. COORDINATE THIS WORK WITH GENERAL CONTRACTOR IN ORDER TO PROPERLY EXPEDITE AND PERFORM THIS WORK.


13. PASSAGE OF EQUIPMENT: CHECK THE DIMENSIONAL REQUIREMENTS OF EQUIPMENT CAN PASS THROUGH THE NECESSARY AREAS TO REACH ITS ULTIMATE INSTALLED LOCATION. INCLUDE IN BID COSTS FOR ALL WORK REQUIRED, INCLUDING ANY WORK REQUIRED TO MOVE THE EQUIPMENT THROUGH THE SITE TO THIS FINAL LOCATION, INCLUDING ANY DISMANTLING AND RE-ASSEMBLY.
  14. SIGNAGE: PROVIDE SIGNAGE REQUIRED BY CODES AND AUTHORITIES HAVING JURISDICTION.
  15. POTENTIAL DELIVERY PROBLEMS: NOTIFY THE GENERAL CONTRACTOR AND ENGINEER IN WRITING, WITHIN FIVE DAYS OF AWARD OF CONTRACT, OF THE PROPOSED DELIVERY SCHEDULE OF ANY EQUIPMENT OR MATERIAL THAT MAY PREVENT THE INSTALLATION FROM BEING COMPLETED BY THE PROJECT COMPLETION DATE.
  16. WARRANTY: SUBMIT A SINGLE GUARANTEE STATING THAT ALL PORTIONS OF THE WORK ARE IN ACCORDANCE WITH CONTRACT REQUIREMENTS. GUARANTEE ALL WORK AGAINST FAULTY AND IMPROPER MATERIAL AND WORKMANSHIP FOR A PERIOD OF ONE YEAR FROM DATE OF FINAL ACCEPTANCE BY OWNER, EXCEPT THAT WHERE GUARANTEES OR WARRANTIES FOR LONGER TERMS ARE SPECIFIED BY CONTRACT, SUCH LONGER TERM SHALL APPLY.
  17. RECTIFICATION: AT NO ADDITIONAL COST TO THE OWNER, WITHIN 24 HOURS AFTER NOTIFICATION, CORRECT ANY DEFICIENCIES WHICH OCCUR DURING THE GUARANTEE PERIODS, ALL TO THE SATISFACTION OF THE OWNER. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ANY DAMAGE CAUSED BY SUCH DEFICIENCIES AND REPAIR THEREOF AND REIMBURSE THE OWNER FOR ALL COSTS INCURRED.
- B. MAJOR ITEMS OF WORK INCLUDE (AS APPLICABLE):**
- A. AIR CONDITIONING SYSTEMS: SUPPLY AND RETURN AIR DISTRIBUTION SYSTEMS, INCLUDING DUCTWORK, SUPPLY AIR DIFFUSERS, CONTROLS AND CONNECTIONS TO EXISTING WORK.
  - B. PIPE AND PIPING ACCESSORIES.
  - C. TESTING AND BALANCING OF ALL SYSTEMS.
  - D. SPRING ISOLATION.
  - E. DEMOLITION OF EXISTING EQUIPMENT, PIPING, AND DUCTWORK.
- C. GENERAL ITEMS:**
- A. CUTTING AND PATCHING FOR MECHANICAL WORK.
  - B. COORDINATE ALL NEW WORK WITH EXISTING INSTALLATIONS.
  - C. CONDENSATE DRAIN LINES SHALL HAVE NO LESS THAN 1% SLOPE.
  - D. CONTRACTOR SHALL INSPECT JOB SITE PRIOR TO BID AND VERIFY EXACT LOCATION, SIZE AND LOADING OF EXISTING PIPING PRIOR TO INSTALLATION AND CONNECTION OF ANY PIPING.

- 1.02 REFERENCE STANDARDS:**
- A. IN ADDITION TO COMPLYING WITH ALL OTHER LEGAL REQUIREMENTS, COMPLY WITH CURRENT PROVISIONS OF GOVERNING CODES AND REGULATIONS IN EFFECT DURING THE PROGRESS OF THE WORK, AND WITH THE FOLLOWING:**
1. DRAWINGS AND SPECIFICATION REQUIREMENTS SHALL GOVERN WHERE THEY EXCEED CODE AND REGULATION REQUIREMENTS.
  2. WHERE REQUIREMENTS BETWEEN GOVERNING CODES AND REGULATIONS VARY, THE MORE STRINGENT SHALL APPLY.
  3. NOTHING CONTAINED IN CONTRACT DOCUMENTS SHALL BE CONSTRUED AS AUTHORITY OR PERMISSION TO DISREGARD OR VIOLATE LEGAL REQUIREMENTS. THE CONTRACTOR SHALL IMMEDIATELY DRAW THE ATTENTION OF ARCHITECT TO ANY SUCH CONFLICTS NOTED IN THE CONTRACT DOCUMENTS.
- 1.03 PERMITS AND INSPECTIONS:**
- A. THE CONTRACTOR SHALL SECURE ALL APPROVALS AND PAY ALL FEES FOR ALL WORK INSTALLED. CERTIFICATE SHALL BE DELIVERED TO OWNER BEFORE FINAL PAYMENT WILL BE MADE.**

- 1.04 DESCRIPTION:**
- A. SPECIFICATIONS ARE OF SIMPLIFIED FORM AND INCLUDE INCOMPLETE SENTENCES, WORDS OR PHRASES SUCH AS "THE CONTRACTOR SHALL", "SHALL BE", "FURNISH", "PROVIDE", "A", "AN", "THE", AND "ALL" HAVE BEEN OMITTED FOR BREVITY.**
- B. DRAWING ARE DIAGRAMMATIC AND INDICATE GENERAL ARRANGEMENT OF SYSTEMS AND WORK. FOLLOW DRAWINGS IN LAYING OUT WORK AND CHECK DRAWINGS OF OTHER TRADES TO VERIFY SPACE CONDITIONS. MAINTAIN HEADROOM AND SPACE CONDITIONS.**
- C. DEFINITIONS:**
1. "FURNISH" OR "PROVIDE": TO SUPPLY, INSTALL AND CONNECT UP COMPLETE AND READY FOR SAFE AND REGULAR OPERATION OF PARTICULAR WORK REFERRED TO UNLESS SPECIFICALLY OTHERWISE NOTED.
  2. "INSTALL": TO ERECT, MOUNT AND CONNECT COMPLETE WITH RELATED ACCESSORIES.
  3. "SUPPLY": TO PURCHASE, PROCURE, ACQUIRE AND DELIVER COMPLETE WITH RELATED ACCESSORIES.
  4. "WORK": LABOR, MATERIALS, EQUIPMENT, APPARATUS, CONTROLS, ACCESSORIES AND OTHER ITEMS REQUIRED FOR PROPER AND COMPLETE INSTALLATION.
  5. "PIPING": PIPE, TUBE, FITTINGS, FLANGES, VALVES, CONTROLS, STRAINERS, HANGERS, SUPPORTS, UNIONS, TRAPS, DRAINS, INSULATION, AND RELATED ITEMS.
  6. "WIRING": RACEWAY, FITTINGS, WIRE, BOXES AND RELATED ITEMS.
  7. "CONCEALED": EMBEDDED IN MASONRY OR OTHER CONSTRUCTION, INSTALLED IN FURRED SPACES, WITHIN DOUBLE PARTITIONS OR HUNG CEILINGS, IN TRENCHES, IN CRAWL SPACES OR IN ENCLOSURES.
  8. "EXPOSED": NOT INSTALLED UNDERGROUND OR "CONCEALED" AS DEFINED ABOVE.
  9. "EQUIVALENT": EQUIVALENT IN MATERIALS, WEIGHT, SIZE, DESIGN AND EFFICIENCY OF SPECIFIED PRODUCT.
- D. SCOPE OF WORK: LABOR, MATERIALS, EQUIPMENT, SERVICES AND FEES NECESSARY FOR COMPLETE SAFE INSTALLATION IN CONFORMITY WITH APPLICABLE CODES AND AUTHORITIES HAVING JURISDICTION: AS INDICATED ON DRAWINGS AND HEREIN SPECIFIED.**

- 1.05 JOB CONDITIONS:**
- A. CONNECTION TO EXISTING WORK:**
1. INSTALL NEW WORK AND CONNECT TO EXISTING WORK WITH MINIMUM INTERFERENCE TO EXISTING FACILITIES.
  2. TEMPORARY SHUTDOWNS OF EXISTING SERVICES.
    - 2.1. AT NO ADDITIONAL CHARGES.
    - 2.2. AT TIMES NOT TO INTERFERE WITH NORMAL OPERATION OF EXISTING FACILITIES.
    - 2.3. ONLY WITH WRITTEN CONSENT OF OWNER.
  3. ALARM AND EMERGENCY SYSTEMS: NOT TO BE INTERRUPTED.
  4. MAINTAIN CONTINUOUS OPERATION OF EXISTING FACILITIES AS REQUIRED WITH NECESSARY TEMPORARY CONNECTION BETWEEN NEW AND EXISTING WORK.
  5. CONNECT NEW WORK TO EXISTING WORK IN NEAT AND ACCEPTABLE MANNER. RESTORE EXISTING DISTURBED WORK TO ORIGINAL CONDITION INCLUDING MAINTENANCE OF WIRING CONTINUITY AS REQUIRED.
- B. REMOVAL AND RELOCATION OF EXISTING WORK:**
1. REMOVE UNUSED PIPING, DUCTWORK AND MATERIAL.

- 1.06 QUALITY ASSURANCE:**
- A. QUALITY AND GAUGES OF MATERIALS:**
1. QUALITY OF MATERIALS:
    - 1.1. NEW, BEST OF THEIR RESPECTIVE KINDS, FREE FROM DEFECTS AND LISTED BY UNDERWRITES' LABORATORIES, INC. AND BEARING THEIR LABEL.
    - 1.2. MATERIALS AND EQUIPMENT OF SIMILAR APPLICATION: SAME MANUFACTURE, EXCEPT AS NOTED.
    - 1.3. CONFORM TO REFERENCE STANDARDS.
  - 1.07 PRODUCT DELIVERY, STORAGE AND HANDLING:
    - A. MOVING OF EQUIPMENT: WHERE NECESSARY, SHIP IN CRATED SECTIONS OF SIZE TO PERMIT PASSING THROUGH AVAILABLE SPACES.
    - B. ACCESSIBILITY:
      1. FOR OPERATION, MAINTENANCE AND REPAIR.
      2. MINOR DEVIATIONS: PERMISSIBLE.
      3. CHANGE OF MAGNITUDE OR INVOLVING EXTRA COST: NOT PERMISSIBLE WITHOUT REVIEW.
      4. GROUP CONCEALED MECHANICAL EQUIPMENT REQUIRING ACCESS WITH EQUIPMENT FREELY ACCESSIBLE THROUGH ACCESS DOORS.
  - 1.08 SUBMITTALS:
    - A. PROVIDE TWO (2) HARD COPIES OR AN ELECTRONIC COPY OF SUBMITTAL MATERIAL WITH DESCRIPTIVE DATA FOR ALL PRODUCTS AND MATERIALS, INCLUDING BUT NOT LIMITED TO THE FOLLOWING, PRIOR TO INSTALLATION. ALL SUBMITTALS SHALL BE HIGHLIGHTED TO INDICATE SPECIFIC PRODUCTS OR MATERIALS BEING USED. ALLOW 10 DAYS FOR ENGINEER TO REVIEW SUBMITTALS.
      1. SHOP DRAWINGS OF NEW INSTALLATIONS SHOWING COMPLIANCE WITH DESIGN INTENT AND FULLY COORDINATED WITH ALL TRADES AND EXISTING BUILDING COMPONENTS AND SYSTEMS.
      2. AIR HANDLING UNIT, CONDENSING UNIT, AND ALL OTHER SCHEDULED EQUIPMENT AND COMPONENTS.
      3. DUCTWORK ACCESSORIES.
      4. DUCTWORK TYPICAL CONSTRUCTION.
      5. DUCT SEALING.
      6. DAMPERS.
      7. AIR TEST AND BALANCE.
      8. PIPE, PIPE SUPPORT, AND PIPING ACCESSORIES.
      9. CONTROLS DRAWINGS.
      10. DIFFUSERS, GRILLES, AND REGISTERS.
      11. VIBRATION ISOLATION.
      12. ONE SET OF AS-BUILT REPRODUCIBLE DRAWINGS.
    - B. PROVIDE 1 COPY OF APPROVED SUBMITTALS TO THE OFFICE OF THE BUILDING ENGINEER.
    - C. SUBMITTALS TRANSMITTED VIA E-MAIL SHALL HAVE A MAXIMUM ATTACHMENT SIZE OF 5MB.
      1. IF TRANSMITTAL OF LARGER FILE IS REQUIRED, CONTRACTOR SHALL CONFIGURE A SECURE FILE TRANSFER LOCATION ACCESSIBLE BY JCC AND ENGINEER REPRESENTATIVES VIA INTERNET AND NOTIFY THE APPROPRIATE PARTIES WHEN FILES HAVE BEEN POSTED TO THAT LOCATION REQUIRING REVIEW.
  - 1.09 MAINTENANCE MANUALS AND AS-BUILT DRAWINGS:
    - A. PROVIDE FOUR (4) COPIES OF OPERATING AND MAINTENANCE MANUAL FOR OWNER'S USE FOR EACH PIECE OF EQUIPMENT. EACH ITEM SHALL BE CROSS-REFERENCED AND NUMBERED WITH AS-BUILT DRAWING DESCRIPTIONS.
    - B. AS-BUILT DRAWINGS: DELIVER TO ENGINEER. ONE SET OF REDLINED MARK-UP, AIR BALANCE REPORT AND PANEL SCHEDULES SHOWING WORK AS ACTUALLY INSTALLED THREE (3) DAYS PRIOR TO FINAL PUNCH WALK.
  - 1.10 SEISMIC SUPPORT:
    - A. CONTRACTOR SHALL SUPPORT AND BRACE ALL NEW HVAC AND PLUMBING SYSTEMS IN ACCORDANCE WITH CODE SEISMIC REQUIREMENTS.

CAVAGNERO  
ARCHITECTS

SYSKA HENNESSY  
group  
A member company of SH Group, Inc.  
Syska Hennessy Group, Inc.  
800 Corporate Pointe  
Suite 200  
Culver City, CA 90230  
Tel: 310.312.0200  
Fax: 310.665.0172  
www.syska.com

REV	DATE	DESCRIPTION
	07/14/2016	100% SD
	08/04/2016	100% DD
	09/13/2016	50% CD
	11/08/2016	90% CD
	01/17/2017	PLAN CHECK #1
	03/09/2017	PERMIT SET
	06/14/2017	100% CD / CONFORMED SET

**EAST COUNTY COURTHOUSE  
ELEVATOR MODERNIZATION**  
250 E Main St, El Cajon, CA 92020



**MECHANICAL SPECIFICATIONS**

**M0.03**



# MECHANICAL SPECIFICATIONS CONTINUED (AS APPLICABLE)

## PART 3 EXECUTION

### 3.01 INSTALLATION OF THE WORK

#### A. THE CONTRACT DRAWINGS INDICATE THE GENERAL ARRANGEMENTS FOR THE HVAC AND PLUMBING SYSTEMS.

1. DRAWINGS ARE DIAGRAMMATIC AND DO NOT INDICATE NECESSARY OFFSETS, OBSTRUCTIONS OR STRUCTURAL CONDITIONS.
2. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO INSTALL THE WORK IN SUCH A MANNER THAT IT WILL BE AT THE HIGHEST ELEVATION POSSIBLE, CONFORM TO THE STRUCTURE, AVOID OBSTRUCTIONS, MAINTAIN HEADROOM, LEAVE ADEQUATE CLEARANCES FOR LIGHT FIXTURES, RETURN AIR PATHWAYS, MAINTENANCE AND REPAIRS, AND PROVIDE CLEARANCE AND ACCESS AS REQUIRED BY CODES. NOTHING SHALL BE INSTALLED BELOW CEILING LEVEL WITHOUT ARCHITECT'S WRITTEN CONSENT.
3. ABOVE ITEMS TO BE PERFORMED AT NO ADDITIONAL COST TO THE OWNER.
4. PROCEED AS RAPIDLY AS THE BUILDING CONSTRUCTION WILL PERMIT.
5. THOROUGHLY CLEAN ITEMS BEFORE INSTALLATION. CAP OPENING TO EXCLUDE DIRT UNTIL FINAL CONNECTION HAS BEEN MADE.
6. CJT MATERIALS ACCURATELY, WORK INTO PLACE WITHOUT SPRINGING OR FORCING, PROPERLY CLEAR WINDOWS, DOORS AND OTHER OPENINGS. EXCESSIVE CUTTING OR OTHER WEAKENING OF THE BUILDING STRUCTURE WILL NOT BE PERMITTED.
7. FIRE CAULK ANY PIPING, CONDUIT PENETRATIONS THRU FIRE RATED PARTITION TO MATCH THE RATING OF THE PARTITION. THE CONTRACTOR SHALL VERIFY THE EXISTING FIRE RATING OF THE PARTITIONS THROUGH WHICH PIPING, CONDUIT PENETRATIONS.
8. MANUFACTURER'S DRAWINGS AND INSTRUCTIONS SHALL BE FOLLOWED IN ALL CASES WHERE THE MAKERS OF DEVICES AND EQUIPMENT FURNISH DIRECTIONS OR DETAILS NOT SHOWN ON THE DRAWINGS OR DESCRIBED IN THE SPECIFICATIONS.
9. DRAWINGS ARE NOT INTENDED TO BE SCALED, BUT SHALL BE FOLLOWED WITH SUFFICIENT ACCURACY TO COORDINATE WITH OTHER WORK AND STRUCTURAL LIMITATIONS.
10. SEISMIC DESIGN: THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL ANCHORS, SUPPORTS AND CONNECTION OF MECHANICAL WORK TO THE BUILDING STRUCTURE TO PREVENT DAMAGE AS A RESULT OF AN EARTHQUAKE, INCLUDING MANUFACTURED EQUIPMENT, THE CONNECTION AND INTEGRITY OF SHOP FABRICATED AND FIELD FABRICATED MATERIALS AND EQUIPMENT. ALL SUPPORTS, EQUIPMENT AND CONNECTIONS THERETO SHALL BE DESIGNED TO CONFORM TO REQUIREMENTS OF THE CALIFORNIA ADMINISTRATIVE CODE, OR OTHER GOVERNING CODES.
11. ALL WORK SHALL BE PROPERLY SUPPORTED FROM BUILDING STRUCTURE AND/OR FRAMING IN AN APPROVED MANNER, INDEPENDENT OF THE CEILING SUPPORT SYSTEM, WHERE OVERHEAD CONSTRUCTION DOES NOT PERMIT DIRECT FASTENING OF SUPPORTS, FURNISH ADDITIONAL FRAMING.
12. ALL EQUIPMENT SHALL BE SECURELY FASTENED TO BUILDING CONSTRUCTION WITH APPROVED SUPPORTS.
13. REFER TO ENGINEERING DRAWINGS FOR EXACT LOCATION OF DIFFUSERS, GRILLES, AND THERMOSTATS.
14. COORDINATE THE WORK OF THIS SECTION WITH THE WORK OF OTHER SECTIONS IN AMPLE TIME FOR PROPER INSTALLATION AND CONNECTION.
15. CAREFULLY CHECK SPACE REQUIREMENTS, INCLUDING SERVICING SPACE REQUIREMENTS, WITH OTHER SECTIONS TO ENSURE THAT ALL EQUIPMENT AND MATERIALS CAN BE INSTALLED IN THE SPACES ALLOTTED THERETO.
16. PREPARE DRAWINGS, ATTEND MEETINGS, OBTAIN ALL APPROVALS REQUIRED BY ALL AUTHORITIES HAVING JURISDICTION, CONDUCT REQUIRED TESTS AND OBTAIN REQUIRED PERMITS.

#### 17. SEISMIC RESTRAINT:

- 17.1. 2016 CALIFORNIA BUILDING CODE
- 17.2. SEISMIC DESIGN CATEGORIES
- 17.3. PROVIDE THE MANUFACTURER'S CERTIFICATE OF COMPLIANCE WHEN REQUIRED BY CONTRACT DOCUMENTS OR REGULATORY AGENCY.
- 17.4. SEISMIC ANCHORAGE SHALL BE PERFORMED ON ALL SUSPENDED, FLOOR-, ROOF- AND WALL-MOUNTED EQUIPMENT. DESIGN SHALL BE PERFORMED AND CERTIFIED BY A REGISTERED PROFESSIONAL ENGINEER.
- 17.5. SEISMIC BRACES SHALL BE LOCATED ON SHOP DRAWINGS INDICATING MEMBER SIZES, ANCHORAGE REQUIREMENTS AND CERTIFICATION FROM A REGISTERED CIVIL OR STRUCTURAL PROFESSIONAL ENGINEER.

## B. GENERAL:

### 1. PAINTING:

- 1.1. PAINT:
  - 1.1.1. BEST GRADE FOR ITS PURPOSE.
  - 1.1.2. DELIVER IN ORIGINAL SEALED CONTAINERS.
  - 1.1.3. APPLY IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS.
  - 1.1.4. COLORS: TO MATCH EXISTING OR AS SELECTED BY ENGINEER.
- 1.2. GALVANIZED IRON PRIMER.
- 1.3. HOT DIPPED GALVANIZED OR DIPPED IN ZINC CHROMATE.
- 1.4. ZINC CHROMATE WITH FINISH TO MATCH SURROUNDINGS.

### 2. CLEANING:

- 2.1. BRUSH AND CLEAN WORK PRIOR TO CONCEALING PAINTING AND ACCEPTANCE.
- 2.2. PAINTED EXPOSED WORK SOILED OR DAMAGED: CLEAN AND REPAIR TO MATCH ADJOINING WORK BEFORE FINAL ACCEPTANCE.
- 2.3. REMOVE DEBRIS FROM INSIDE AND OUTSIDE OF MATERIAL AND EQUIPMENT.

### 3. CUTTING AND PATCHING: AS REQUIRED FOR NEW WORK.

### 3.02 TESTING AND BALANCING

#### A. GENERAL:

1. ADJUSTMENT: EACH PIECE OF EQUIPMENT AND ALL OF THE SYSTEMS SHALL BE ADJUSTED TO INSURE PROPER FUNCTIONING OF ALL CONTROLS, AND SHALL BE LEFT IN OPERATING CONDITION.
2. PRELIMINARY OPERATION: THE OWNER RESERVES THE RIGHT TO OPERATE ANY SYSTEMS OR EQUIPMENT PRIOR TO FINAL COMPLETION AND ACCEPTANCE OF THE WORK. SUCH PRELIMINARY OPERATION SHALL NOT BE CONSTRUED AS AN ACCEPTANCE OF ANY WORK.

#### B. AIR DISTRIBUTION SYSTEMS:

1. BALANCE AND ADJUST AIR DISTRIBUTION SYSTEM TO QUANTITIES INDICATED ON DRAWINGS IN ACCORDANCE WITH ASSOCIATED AIR BALANCE COUNCIL (AABC) MANUAL OR NEBB STANDARDS, LATEST EDITION.
2. BALANCING AND TESTING SHALL BE PERFORMED AND SUPERVISED BY A CERTIFIED INDEPENDENT FIRM SPECIALIZING IN TESTING AND BALANCING. FIRM SHALL BE A MEMBER OF AABC. TEST REPORTS SHALL BE SUBMITTED IN BOUND FOLDERS AND ON AABC TYPE REPORT FORMS. ALL DIFFUSERS SHALL BE IDENTIFIED BY DESIGNATIONS ON DRAWINGS.
3. DIFFUSER AIR DELIVERY SHALL NOT BE LESS THAN NOR EXCEED BY MORE THAN 5% THE AIR DELIVERY INDICATED ON THE PLANS.
4. UPON COMPLETION OF THE INSTALLATION, CONTRACTOR SHALL REBALANCE ANY AIR DISTRIBUTION SYSTEM AFFECTED BY THE RENOVATION, INCLUDING TERMINAL AIR UNITS AND AIR OUTLETS.
5. CONTRACTOR SHALL CONSTRUCT, SEAL, AND TEST PER 2016 TITLE 24 REQUIREMENTS.
6. PROVIDE WRITTEN REPORT OF ALL TEST RESULTS WITHIN ONE WEEK OF COMPLETION OF BALANCING. NOTE ALL DEFICIENCIES AND FIELD OBSERVATIONS.

#### C. HYDRONIC SYSTEMS:

1. PREPARE TEST REPORTS WITH PERTINENT DESIGN DATA AND NUMBER IN SEQUENCE STARTING AT PUMP TO END OF SYSTEM. CHECK THE SUM OF BRACH-CIRCUITS FLOWS AGAINST APPROVED PUMP FLOW RATE. CORRECT VARIATIONS THAT EXCEED PLUS OR MINUS 5 PERCENT.
2. PREPARE SCHEMATIC DIAGRAMS OF SYSTEMS' "AS-BUILT" PIPING LAYOUTS.
3. PREPARE HYDRONIC SYSTEMS FOR TESTING AND BALANCING ACCORDING TO THE FOLLOWING, IN ADDITION TO THE GENERAL PREPARATION PROCEDURES SPECIFIED ABOVE:
  - 3.1. OPEN ALL MANUAL VALVES FOR MAXIMUM FLOW.
  - 3.2. CHECK EXPANSION TANK LIQUID LEVEL.
  - 3.3. CHECK MAKEUP-WATER-STATION PRESSURE GAGE FOR ADEQUATE PRESSURE FOR HIGHEST VENT.
  - 3.4. CHECK FLOW-CONTROL VALVES FOR SPECIFIED SEQUENCE OF OPERATION AND SET AT INDICATED FLOW.
  - 3.5. SET DIFFERENTIAL-PRESSURE CONTROL VALVES AT THE SPECIFIED DIFFERENTIAL PRESSURE. DO NOT SET AT FULLY CLOSED POSITION WHEN PUMP IS POSITIVE-DISPLACEMENT TYPE UNLESS SEVERAL TERMINAL VALVES ARE KEPT OPEN.
  - 3.6. SET SYSTEM CONTROLS SO AUTOMATIC VALVES ARE WIDE OPEN TO HEAT EXCHANGERS.
  - 3.7. CHECK PUMP-MOTOR LOAD. IF MOTOR IS OVERLOADED, THROTTLE MAIN FLOW-BALANCING DEVICE SO MOTOR NAMEPLATE RATING IS NOT EXCEEDED.
  - 3.8. CHECK AIR VENTS FOR A FORCEFUL LIQUID FLOW EXITING FROM VENTS WHEN MANUALLY OPERATED.

## 3.03 PROJECT CLOSE-OUT

- D. AFTER FINAL OPERATION FOR INSPECTION AND ACCEPTANCE, DELIVER ALL COPIES OF OPERATION INSTRUCTIONS, MAINTENANCE MANUALS AND PARTS DESCRIPTIONS TO THE ENGINEER.
- E. ALL TOOLS SUPPLIED WITH THE EQUIPMENT FOR MAINTENANCE SHALL BE TAGGED AND TEMPORARILY SECURED TO THE UNIT, OR TURNED OVER TO THE BUILDING ENGINEER.

END OF SECTION



REV	DATE	DESCRIPTION
	07/14/2016	100% SD
	08/04/2016	100% DD
	09/13/2016	50% CD
	11/08/2016	90% CD
	01/17/2017	PLAN CHECK #1
	03/09/2017	PERMIT SET
	06/14/2017	100% CD / CONFORMED SET

EAST COUNTY COURTHOUSE  
ELEVATOR MODERNIZATION  
250 E Main St, El Cajon, CA 92020



MECHANICAL SPECIFICATIONS

M0.05

STATE OF CALIFORNIA  
**MECHANICAL SYSTEMS**  
 CEC-NRCC-MCH-01-E (Revised 01/16)  
 CALIFORNIA ENERGY COMMISSION  
 CERTIFICATE OF COMPLIANCE NRCC-MCH-01-E  
 Mechanical Systems (Page 2 of 2)  
 Project Name: EAST COUNTY COURTHOUSE ELEVATOR MODERNIZATION Date Prepared: 2017/06/12

**MECHANICAL HVAC ACCEPTANCE FORMS (check box for required forms)**

**Designer:**  
 This form is to be used by the designer and attached to the plans. Listed below are all the acceptance tests for HVAC systems. The designer is required to check the applicable boxes for all acceptance tests that apply and list all equipment that requires an acceptance test. All equipment of the same type that requires a test, list the equipment description and the number of systems.

**Installing Contractor:**  
 The contractor who installed the equipment is responsible to either conduct the acceptance test them self or have a qualified entity run the test for them. If more than one person has responsibility for the acceptance testing, each person shall sign and submit the Certificate of Acceptance applicable to the portion of the construction or installation for which they are responsible. The following tests require a

**Enforcement Agency:**  
 Plancheck - The NRCC.MCH.01.E form is not considered a completed form and is not to be accepted by the building department unless the correct boxes are checked. Inspector. Before occupancy permit is granted all newly installed process systems must be tested to ensure proper operations.

Test Description	MCH.12A	MCH.13A	MCH.14A	MCH.15A	MCH.16A	MCH.17A	MCH.18A
Equipment Requiring Testing or Verification	Fault Detection & Diagnostics for DX Units	Automatic Fault Detection & Diagnostics for Air & Zone	Distributed Energy Storage DX AC Systems	Thermal Energy Storage (TES) Systems	Supply Air Temperature Reset Controls	Condenser Water Reset Controls	ECMS
(N) AHU/HP	4	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

STATE OF CALIFORNIA  
**MECHANICAL SYSTEMS**  
 CEC-NRCC-MCH-00-E (Revised 01/16)  
 CALIFORNIA ENERGY COMMISSION  
 CERTIFICATE OF COMPLIANCE NRCC-MCH-00-E  
 Mechanical Systems (Page 1 of 1)  
 Project Name: EAST COUNTY COURTHOUSE ELEVATOR MODERNIZATION Date Prepared: 2017/06/12

**DOCUMENTATION AUTHOR'S DECLARATION STATEMENT**

1. I certify that this Certificate of Compliance documentation is accurate and complete.

Documentation Author Name: JOEL SOLIS  
 Signature Date: 2017/06/12  
 Company: SYSKA HENNESSY GROUP INC.  
 Address: 800 CORPORATE POINTE, STE 200  
 City/State/Zip: CULVER CITY, CA 90230  
 Phone: (310) 254-3658

**RESPONSIBLE PERSON'S DECLARATION STATEMENT**

I certify the following under penalty of perjury, under the laws of the State of California:

- The information provided on this Certificate of Compliance is true and correct.
- I am eligible under Division 3 of the Business and Professions Code to accept responsibility for the building design or system design identified on this Certificate of Compliance (responsible designer).
- The energy features and performance specifications, materials, components, and manufactured devices for the building design or system design identified on this Certificate of Compliance conform to the requirements of Title 24, Part 1 and Part 6 of the California Code of Regulations.
- The building design features or system design features identified on this Certificate of Compliance are consistent with the information provided on other applicable compliance documents, worksheets, calculations, plans and specifications submitted to the enforcement agency for approval with this building permit application.
- I will ensure that a completed signed copy of this Certificate of Compliance shall be made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Compliance is required to be included with the documentation the

Responsible Designer Name: NATHAN KIRBY  
 Responsible Designer Signature: [Signature]  
 Company: SYSKA HENNESSY GROUP INC.  
 Date Signed: 2017/06/12  
 Address: 800 CORPORATE POINTE, STE 200  
 License: M35696  
 City/State/Zip: CULVER CITY, CA 90230  
 Phone: (310) 312-0200

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

STATE OF CALIFORNIA  
**HVAC SYSTEM REQUIREMENTS**  
 CEC-NRCC-MCH-02-E (Revised 01/16)  
 CALIFORNIA ENERGY COMMISSION  
 CERTIFICATE OF COMPLIANCE NRCC-MCH-02-E  
 HVAC Dry System Requirements (Page 1 of 2)  
 Project Name: EAST COUNTY COURTHOUSE ELEVATOR MODERNIZATION Date Prepared: 06/12/2016

Equipment Tags and System Description	(N) AHU/HP			
<b>MANDATORY MEASURES</b>	<b>Reference to the Requirements in the Contract</b>			
Heating Equipment Efficiency	T-24 Sections 110.1 or 110.2(a)	N/A		
Cooling Equipment Efficiency	110.1 or 110.2(a)	N/A		
HVAC or Heat Pump Thermostats	110.2(b), 110.2(c)	PROCESS		
Furnace Standby Loss Control	110.2(d)	N/A		
Low leakage AHUs	110.2(f)	N/A		
Ventilation	120.1(b)	N/A		
Demand Control Ventilation	120.1(c)4	N/A		
Occupant Sensor Ventilation Control	120.1(c)5, 120.2(e)3	N/A		
Shutoff and Reset Controls	120.2(e)	N/A		
Outdoor Air and Exhaust Damper Control	120.2(f)	N/A		
Isolation Zones	120.2(g)	N/A		
Automatic Demand Shed Controls	120.2(h)	N/A		
Economizer FDD	120.2(i)	N/A		
Duct Insulation	120.4	M0.07		
<b>PRESCRIPTIVE MEASURES</b>				
Equipment is sized in conformance with 140.4 (a & b)	140.4(a & b)	Y/N	Y/N	Y/N
Supply Fan Pressure Control	140.4(c)	N/A		
Simultaneous Heat/Cool	140.4(d)	N/A		
Economizer	140.4(e)	N/A		
Heat and Cool Air Supply Reset	140.4(f)	N/A		
Electric Resistance Heating	140.4(g)	N/A		
Duct Leakage Sealing and Testing	140.4(i)	N/A		

**Notes:**

- Provide equipment tags (e.g. AHU 1 to 10) and system description (e.g. Single Duct VAV reheat) as appropriate. Multiple units with common requirements can be grouped together.
- Provide references to plans (i.e. Drawing Sheet Numbers) and/or specifications (including Section name/number and relevant paragraphs) where each requirement is specified. Enter "N/A" if the requirement is not applicable to this system.
- The referenced plans and specifications must include all of the following information: equipment tag, equipment nominal capacity, Title 24 minimum efficiency requirements, and actual rated equipment efficiencies. Where multiple efficiency requirements are applicable (e.g. full- and part-load) include all. Where appliance standards apply (110.1), identify where equipment is required to be listed per Title 20 1601 et seq.
- Identify where the ventilation requirements are documented for each central HVAC system. Include references to both central unit schedules and sequences of operation. If one or more space is naturally ventilated identify where this is documented in the plans and specifications. Multiple zone central air systems must also provide a MCH-03-E form.
- If one or more space has demand controlled ventilation identify where it is specified including the sensor specifications and the sequence of operation.
- If one or more space has occupant sensor ventilation control identify where it is specified including the sensor specifications and the sequence of operation.
- If the system is DDC identify the sequences for the system start/stop, optimal start, setback (if required) and setup (if required). For all systems identify the specification for the thermostats and time clocks (if applicable).
- Identify where the heating, cooling and deadband airflows are scheduled for this system. Include a reference to the specification of the zone controls. Provide a MCH-03-E form.
- Enter N/A if there is no electric heating. If the system has electric heating indicate which exception to 140.4(g) applies.

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

STATE OF CALIFORNIA  
**MECHANICAL SYSTEMS**  
 CEC-NRCC-MCH-01-E (Revised 01/16)  
 CALIFORNIA ENERGY COMMISSION  
 CERTIFICATE OF COMPLIANCE NRCC-MCH-01-E  
 Mechanical Systems (Page 1 of 2)  
 Project Name: EAST COUNTY COURTHOUSE ELEVATOR MODERNIZATION Date Prepared: 2017/06/12

**MECHANICAL COMPLIANCE FORMS & WORKSHEETS (check box if worksheet is included)**

For detailed instructions on the use of this and all Energy Efficiency Standards compliance forms, refer to the 2016 Nonresidential Manual Note. The Enforcement Agency may require all forms to be incorporated onto the building plans.

YES	NO	Form/Worksheet #	Title
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCC-MCH-00-E (Part 1 of 1)	Certificate of Compliance, Declaration. Required on plans for all submittals.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCC-MCH-01-E (Part 1 of 2)	Certificate of Compliance, Required Acceptance Tests (MCH.02A to 11A). Required on plans for all submittals.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCC-MCH-01-E (Part 2 of 2)	Certificate of Compliance, Required Acceptance Tests (MCH.12A to 18A). Required on plans where applicable.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCC-MCH-02-E (Part 1 of 2)	Mechanical Dry Equipment Summary is required for all submittals with Central Air Systems. It is optional on plans.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	NRCC-MCH-02-E (Part 2 of 2)	Mechanical Wet Equipment Summary is required for all submittals with chilled water, hot water or condenser water systems. It is optional on plans.
<input type="checkbox"/>	<input checked="" type="checkbox"/>	NRCC-MCH-03-E	Mechanical Ventilation and Reheat is required for all submittals with multiple zone heating and cooling systems. It is optional on plans.

**MECHANICAL HVAC ACCEPTANCE FORMS (check box for required forms)**

**Designer:**  
 This form is to be used by the designer and attached to the plans. Listed below are all the acceptance tests for HVAC systems. The designer is required to check the applicable boxes for all acceptance tests that apply and list all equipment that requires an acceptance test. All equipment of the same type that requires a test, list the equipment description and the number of systems.

**Installing Contractor:**  
 The contractor who installed the equipment is responsible to either conduct the acceptance test them self or have a qualified entity run the test for them. If more than one person has responsibility for the acceptance testing, each person shall sign and submit the Certificate of Acceptance applicable to the portion of the construction or installation for which they are responsible.

**Enforcement Agency:**  
 Plancheck - The NRCC.MCH.01.E form is not considered a completed form and is not to be accepted by the building department unless the correct boxes are checked. Inspector.

Test Description	MCH.02A	MCH.03A	MCH.04A	MCH.05A	MCH.06A	MCH.07A	MCH.08A	MCH.09A	MCH.10A	MCH.11A
Equipment Requiring Testing or Verification	Outdoor Air	Single Zone Unitary	Air Distribution Ducts	Economizer Controls	Demand Control Ventilation (DCV)	Supply Fan VAV	Valve Leakage Test	Supply Water Temp. Reset	Hydronic System Variable Flow Control	Automatic Demand Shed Control
(N) AHU/HP	4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

CA Building Energy Efficiency Standards - 2016 Nonresidential Compliance January 2016

**CAVAGNERO**  
 ARCHITECTS

**SYSKA HENNESSY group**  
 A member company of SH Group, Inc.  
 Syska Hennessy Group, Inc.  
 800 Corporate Pointe  
 Suite 200  
 Culver City, CA 90230  
 Tel: 310.312.0200  
 Fax: 310.665.0172  
 www.syska.com

REV	DATE	DESCRIPTION
07/14/2016	100% SD	
08/04/2016	100% DD	
09/13/2016	50% CD	
11/08/2016	90% CD	
01/17/2017	PLAN CHECK #1	
03/09/2017	PERMIT SET	
06/14/2017	100% CD / CONFORMED SET	

**EAST COUNTY COURTHOUSE ELEVATOR MODERNIZATION**  
 250 E Main St, El Cajon, CA 92020

**MECHANICAL TITLE 24 ENERGY COMPLIANCE FORMS**

**M0.06**

**MECHANICAL MANDATORY MEASURES: NONRESIDENTIAL (Page 2 of 2) MECH-MM**

§ 120.1(c).4.	<p>A. CO<sub>2</sub> sensors shall be installed in each room with no less than one sensor per 10,000 ft<sup>2</sup> of floor space. Signal from any sensor indicating that CO<sub>2</sub> is near or at the set point within a space shall trigger an increase in ventilation to the space (controls shall maintain CO<sub>2</sub> concentrations less than or equal to 600 ppm plus the outdoor air CO<sub>2</sub> concentration).</p> <p>B. CO<sub>2</sub> sensors shall be located in the room between 3ft and 6ft above the floor or at the anticipated height of the occupants heads, and shall have suitable coverage to detect occupants in the entire ventilated space.</p> <p>F. CO<sub>2</sub> sensors shall be certified by the manufacturer to be accurate to within 75 ppm at a 600 and 1000 ppm concentration (when measured at sea level and 25°C), shall be factory calibrated and certified by the manufacturer to require calibration no more frequently than once every 5 years. Detection of sensor failure shall prompt the system to provide a signal resetting the supply minimum of outside air levels to meet levels specified in the plans.</p> <p>G. CO<sub>2</sub> sensor readings for each zone shall be displayed continuously and recorded with DDC to the zone level.</p>
---------------	---

**MECHANICAL MANDATORY MEASURES: NONRESIDENTIAL (Page 1 of 2) MECH-MM**

<b>Equipment and System Efficiencies</b>	
§ 110.1	Any appliance for which there is a California standard established in the Appliance Efficiency Regulations will comply with the applicable standard.
§ 120.4(a)	Air distribution duct systems shall be installed, sealed and insulated to meet the requirements of the 2016 CMC Sections 601, 602, 603, 604, 605, and ANSI/SMACNA-006-2006 HVAC Duct Construction Standards Metal and Flexible (3rd edition). Portions of supply or return air conveying heated or cooled air in any unconditioned space shall be insulated to a minimum installed level of R-8.
§ 120.4(b)	All duct and plenum materials (including collars, connections, and splices) for factory- and field-fabricated duct systems shall comply with UL 181, and be labeled as complying with UL 181.
§ 120.3	Piping for all space-conditioning and service water-heating systems, except that conveying fluids between 60°F and 105°F, shall be insulated in accordance with Standards Section 120.3.
§ 120.3 & § 120.4(f)	All insulation shall be protected from damage (including that due to sunlight, moisture, maintenance, and wind). Insulation exposed to weather shall be protected and suitable for outdoor service (protected by aluminum, sheet metal, painted canvas, plastic cover). Cellular foam insulation shall be protected as previously stated or painted with a coating that is water-retardant and provides shielding from solar radiation.
<b>Controls</b>	
§ 120.2(a&b)	Each space conditioning system shall be controlled by an individual thermostat that responds to temperature within the zone. Where used to control heating, the control shall be adjustable down to 55°F or lower. For cooling, control shall be adjustable up to 85°F or higher. Where used to control both heating and cooling, the control shall be capable of providing a deadband of at least 5°F within which the supply of heating and cooling is shut off or reduced to a minimum.
§ 120.2(d)	All heat pumps shall be installed with controls to prevent electric resistance supplementary operation when the heating load can be met by the heat pump alone.
§120.2(e).1.	Each space conditioning system shall be capable of automatically shutting off the system during periods of nonuse and shall have: <ul style="list-style-type: none"> <li>A. An automatic time switch control device complying with Standards Section 110.9, with an accessible manual override that allows operation of the system for up to 4 hours; or</li> <li>B. An occupancy sensor; or</li> <li>C. A 4-hour timer that can be manually operated.</li> </ul>
§120.2(e).2.	Each space conditioning system shall be installed with controls that temporarily restart and temporarily operate the system as required to maintain a setback and/or a setup cooling thermostat setpoint.
§ 120.2(f)	Except in areas where equipment must operate continuously and where prohibited by other provisions of law, outdoor air supply and exhaust equipment shall be installed with dampers that automatically close upon fan shutdown.
§ 120.2(g)	Each space conditioning system serving multiple zones with a combined conditioned floor area more than 25,000 square feet shall be provided with isolation zones. Each zone: shall not exceed 25,000 sq. feet; shall be provided with isolation devices, such as valves or dampers that allow the supply of heating or cooling to be setback or shut down independently of other isolation areas; and shall be controlled by a time control device as described above.
§ 120.2(h)	<p>HVAC systems with DDC to the Zone level shall be programmed to allow centralized demand shed for non-critical zones as follows:</p> <ol style="list-style-type: none"> <li>1. The controls shall have a capability to remotely setup the operating cooling temperature set points by 4 degrees or more in all non-critical zones on signal from a centralized contact or software point within an Energy Management Control System (EMCS).</li> <li>2. The controls shall have a capability to remotely setdown the operating heating temperature set points by 4 degrees or more in all non-critical zones on signal from a centralized contact or software point within an EMCS.</li> <li>3. The controls shall have capabilities to remotely reset the temperatures in all non-critical zones to original operating levels on signal from a centralized contact or software point within an EMCS.</li> <li>4. The controls shall be programmed to provide an adjustable rate of change for the temperature setup and reset.</li> <li>5. The controls shall have the following features:                             <ul style="list-style-type: none"> <li>A. Disabled. Disabled by authorized facility operators; and</li> <li>B. Manual control. Manual control by authorized facility operators to allow adjustment of heating and cooling set points globally from a single point in the EMCS; and</li> <li>C. Automatic Demand Shed Control. Upon receipt of a demand response signal, the space-conditioning systems shall conduct a centralized demand shed, as specified in Sections 120.2(h)1 and 120.2(h)2, for non-critical zones during the demand response period.</li> </ul> </li> </ol>
<b>Ventilation</b>	
§ 120.1(e)	Controls shall be provided to allow outside air dampers or devices to be operated at the specified ventilation rates. All variable air volume mechanical ventilation and space conditioning systems shall include dynamic controls that maintain measured outside air ventilation rates within 10 percent of specified ventilation rates.



REV	DATE	DESCRIPTION
	07/14/2016	100% SD
	08/04/2016	100% DD
	09/13/2016	50% CD
	11/08/2016	90% CD
	01/17/2017	PLAN CHECK #1
	03/09/2017	PERMIT SET
	06/14/2017	100% CD / CONFORMED SET

**EAST COUNTY COURTHOUSE ELEVATOR MODERNIZATION**  
 250 E Main St, El Cajon, CA 92020



**MECHANICAL TITLE 24 ENERGY COMPLIANCE FORMS**

**M0.07**

**SPLIT SYSTEM DX AIR HANDLING UNIT SCHEDULE**

TAG	SERVICE	LOCATION	REFRIGERANT	EVAPORATOR FAN			COOLING CAPACITY				HEATING CAPACITY				FILTER		ELECTRIC DATA		VIBRATION ISOLATION			OPERATING WEIGHT (LB)	DIMENSIONS			MANUFACTURER	MODEL	NOTES						
				CFM	ESP (IN WG)	MOTOR			EAT		LAT		CAPACITY (MBH)		EAT		LAT		HEATING CAPACITY (MBH)	TYPE	QTY.		SIZE (IN.)	V/PH/Hz	FLA / MCA / MOCp				SPECIFICATION		MIN. STATIC DEFLECTION (IN)	LENGTH (IN)	WIDTH (IN)	HEIGHT (IN)
						TYPE	QTY.	RPM	DB °F	WB °F	DB °F	WB °F	TOTAL	SENSIBLE	DB °F	WB °F	DB °F	WB °F											MOUNTING TYPE	BASE TYPE				
AHU-6	SIXTH FLOOR EMR	SIXTH FLOOR EMR	R-410A	700	0.3	ECM	1	-	85	67	55	53	23.6	23.6	55	46	90	62	27.3	ANTI-ALLERGY ENZYME	1	-	208 / 1 / 60	0.76 / 1 / -	WALL MOUNTED	-	-	37	43.3	9.4	12.8	mitsubishi	MSZ-GL24NA-U1	1, 2
AHU-9A	NINTH FLOOR EMR	NINTH FLOOR EMR	R-410A	700	0.3	ECM	1	-	85	67	55	53	23.9	23.9	55	46	90	62	27.5	ANTI-ALLERGY ENZYME	1	-	208 / 1 / 60	0.76 / 1 / -	WALL MOUNTED	-	-	37	43.3	9.4	12.8	mitsubishi	MSZ-GL24NA-U1	1, 2
AHU-5B	FIFTH FLOOR EMR	FIFTH FLOOR EMR	R-410A	400	0.3	ECM	1	-	85	67	55	53	7.1	7.1	55	46	90	62	8.2	ANTI-ALLERGY ENZYME	1	-	208 / 1 / 60	0.76 / 1 / -	WALL MOUNTED	-	-	22	31.6	9.1	11.6	mitsubishi	MSZ-GL12NA-U1	1, 2
AHU-10	TENTH FLOOR EMR	TENTH FLOOR EMR	R-410A	2,000	0.5	BELT-DRIVE CENTRIF.	2	1,725	85	67	55	53	61.6	61.6	55	46	90	62	71.2	MERV 13	4	16 x 24 x 2	208 / 3 / 60	10.8 / 14 / 20	SPRING ISOLATOR	-	1	381	56.1	49.0	28.2	CARRIER	40RUQA07T3A6	1, 2

NOTES:  
 1. PROVIDE UNIT WITH STAINLESS STEEL PRIMARY DRAIN PAN, CONDENSATE PUMP, 7-DAY PROGRAMMABLE THERMOSTAT, SWEAT ADAPTER KIT, AND DISCONNECT SWITCH.  
 2. UNIT SHALL OPERATE 24/7.  
 3. PROVIDE CONDENSATE PUMP "LITTLE GIANT" VCL-24ULS 120V, 1/18 HP, 230 GPH AT 7' HEAD, WITH SAFETY SWITCH.

**AIR COOLED HEAT PUMP UNIT SCHEDULE**

UNIT NO.	SERVICE	LOCATION	REFRIGERANT	NOMINAL CAPACITY (TONS)	AMBIENT AIR TEMP. (°F)	CONDENSER COIL		CONDENSER FAN(S)				COMPRESSOR(S)		ELECTRIC DATA		DIMENSIONAL DATA		VIBRATION ISOLATION			BASIS OF DESIGN		NOTES
						FACE AREA (SQ. FT.)	NO. OF ROWS	TYPE	QTY.	CFM (TOTAL)	RPM	NO.	TYPE	V/PH/Hz	FLA / MCA / MOCp	LxWxH (IN)	WEIGHT (LB.)	SPECIFICATION		MIN. STATIC DEFLECTION (IN)	MANUFACTURER	MODEL NO.	
																		MOUNTING TYPE	BASE TYPE				
HP-6	AHU-6	NINTH FLOOR ROOF	R-410A	2	100	-	-	ECM	1	1700	-	1	DC INVERTER	208 / 1 / 60	- / 17.1 / 20	36.2 / 14.2 / 34.6	119	NEOPRENE PADS	ROOF CURB	0.25	mitsubishi	MUZ-GL24-NA-U1	1
HP-9A	AHU-9A	NINTH FLOOR ROOF	R-410A	2	100	-	-	ECM	1	1700	-	1	DC INVERTER	208 / 1 / 60	- / 17.1 / 20	36.2 / 14.2 / 34.6	119	NEOPRENE PADS	ROOF CURB	0.25	mitsubishi	MUZ-GL24-NA-U1	1
HP-9B	AHU-9B	NINTH FLOOR ROOF	R-410A	1.5	100	-	-	ECM	1	1700	-	1	DC INVERTER	208 / 1 / 60	- / 9 / 15	36.2 / 14.2 / 34.6	121	NEOPRENE PADS	ROOF CURB	0.25	mitsubishi	MUZ-GL12-NA-U1	1
HP-10	AHU-10	NINTH FLOOR ROOF	R-410A	6	100	-	-	DIRECT PROP.	2	6,000	-	1	2-STAGE SCROLL	208 / 3 / 60	38 / 40 / 60	59.3 / 46.0 / 42.3	444	NEOPRENE PADS	ROOF CURB	0.25	CARRIER	38AUQD07A0A6	1

NOTES:  
 1. PROVIDE UNIT WITH FACTORY INSTALLED DISCONNECT SWITCH.

**DIFFUSER SCHEDULE**

MARK NO.	TYPE	CFM RANGE	MAX. SP (IN.)	FRAME SIZE	NECK SIZE	MAX N.C.	REMARKS
SG-1	SUPPLY GRILLE	0-500	0.06	12 X 12	12 X 12	30	TITUS 300FL - DUCTED LOUVERED SUPPLY

NOTES:  
 1. COORDINATE FRAME STYLE WITH FRAMING.  
 2. OBTAIN ARCHITECT'S APPROVAL FOR FINISH.

**BRANCH DUCT SCHEDULE**

CFM	ROUND DUCT (IN)	RECTANGULAR DUCT (IN)					
		W x 4	W x 6	W x 8	W x 10	W x 12	W x 14
UP TO 120	6	8	6	X	X	X	X
120 - 150	8	10	8	X	X	X	X
151 - 240	8	16	10	8	X	X	X
241 - 320	10	X	12	10	X	X	X
321 - 420	10	X	16	12	10	X	X
421 - 500	12	X	X	14	10	X	X
501 - 660	12	X	X	16	12	X	X
661 - 850	14	X	X	20	14	12	X
851 - 1000	14	X	X	22	16	14	X
1001 - 1200	16	X	X	26	20	16	14
1201 - 1400	16	X	X	30	24	18	16
1401 - 1700	X	X	X	34	26	20	18

NOTES:  
 1. THIS SCHEDULE APPLIES TO BRANCH DUCT TO INDIVIDUAL DIFFUSERS THAT ARE NOT SIZED ON PLANS.  
 2. APPLICABLE FOR LOW PRESSURE DUCT WORK ONLY (<2" WG).  
 3. "W" INDICATED IN THE SCHEDULE IS DUCT WIDTH.




REV	DATE	DESCRIPTION
07/14/2016	100% SD	
08/04/2016	100% DD	
09/13/2016	50% CD	
11/08/2016	90% CD	
01/17/2017	PLAN CHECK #1	
03/09/2017	PERMIT SET	
06/14/2017	100% CD / CONFORMED SET	

**EAST COUNTY COURTHOUSE ELEVATOR MODERNIZATION**  
 250 E Main St, El Cajon, CA 92020



**MECHANICAL SCHEDULES**





1 SIXTH FLOOR MECHANICAL PLAN  
M2.06 1/16" = 1'-0"



A member company of SH Group, Inc.  
Syska Hennessy Group, Inc.  
800 Corporate Pointe  
Suite 200  
Culver City, CA 90230  
Tel: 310.312.0200  
Fax: 310.665.0172  
www.syska.com


REV	DATE	DESCRIPTION
	07/14/2016	100% SD
	08/04/2016	100% DD
	09/13/2016	50% CD
	11/08/2016	90% CD
	01/17/2017	PLAN CHECK #1
	03/09/2017	PERMIT SET
	06/14/2017	100% CD / CONFORMED SET

EAST COUNTY  
COURTHOUSE  
ELEVATOR MODERNIZATION  
250 E Main St, El Cajon, CA 92020



SIXTH FLOOR  
MECHANICAL PLAN

M2.06



1 NINTH FLOOR MECHANICAL PLAN  
 M2.09 1/16" = 1'-0"



A member company of SH Group, Inc.  
 Syska Hennessy Group, Inc.  
 800 Corporate Pointe  
 Suite 200  
 Culver City, CA 90230  
 Tel: 310.312.0200  
 Fax: 310.665.0172  
 www.syska.com


REV	DATE	DESCRIPTION
	07/14/2016	100% SD
	08/04/2016	100% DD
	09/13/2016	50% CD
	11/08/2016	90% CD
	01/17/2017	PLAN CHECK #1
	03/09/2017	PERMIT SET
	08/14/2017	100% CD / CONFORMED SET

**EAST COUNTY COURTHOUSE**  
**ELEVATOR MODERNIZATION**  
 250 E Main St, El Cajon, CA 92020



**NINTH FLOOR MECHANICAL PLAN**

**M2.09**



1 TENTH FLOOR MECHANICAL PLAN  
M2.10 1/16" = 1'-0"



**SYSKA HENNESSY**  
group  
A member company of SH Group, Inc.  
Syska Hennessy Group, Inc.  
800 Corporate Pointe  
Suite 200  
Culver City, CA 90230  
Tel: 310.312.0200  
Fax: 310.665.0172  
www.syska.com


REV	DATE	DESCRIPTION
	07/14/2016	100% SD
	08/04/2016	100% DD
	09/13/2016	50% CD
	11/08/2016	90% CD
	01/17/2017	PLAN CHECK #1
	03/09/2017	PERMIT SET
	08/14/2017	100% CD / CONFORMED SET

**EAST COUNTY  
COURTHOUSE  
ELEVATOR MODERNIZATION**  
250 E Main St, El Cajon, CA 92020



**TENTH FLOOR  
MECHANICAL PLAN**

**M2.10**



**KEY NOTES**

- ROUTE (N) CONDENSATE DRAIN TO (E) APPROVED RECEPTACLE (FS/RD). MINIMUM 1" AIR GAP AT DISCHARGE.
- ALL EXISTING WALL/ROOF OPENINGS AND/OR LOUVERS WITHIN THE INDICATED ELEVATOR MACHINE ROOM SHALL BE DEMOLISHED AND SEALED.
- (N) REFRIGERANT LINES CONNECTING BETWEEN (N) AHU IN SIXTH FLOOR ELEVATOR MACHINE ROOM TO (N) HP ON NINTH FLOOR ROOF. CONTRACTOR TO COORDINATE WITH FIELD CONDITIONS FOR EXACT PIPE ROUTING.

**GENERAL NOTES**


- EXISTING CONDITIONS ARE PER AS-BUILT DRAWINGS AND SYSKA SITE SURVEY. CONTRACTOR TO VERIFY EXISTING CONDITIONS PRIOR TO DEMOLITION AND INSTALLATION OF ANY WORK.
- INSPECT DUCT INSULATION ON ALL REUSED EXISTING DUCTWORK AFTER DEMOLITION AND REPAIR OR PROVIDE NEW INSULATION WHERE EXISTING IS DAMAGED OR MISSING.
- CONTRACTOR SHALL COORDINATE ALL HVAC AND BUILDING CONTROLS, SEQUENCES OF OPERATION, AND INTERLOCKS FOR THE SPACE WITH THE CHIEF BUILDING ENGINEER TO ENSURE THAT ALL WORK IS IN CONFORMANCE WITH THE BUILDING REQUIREMENTS.
- NO EQUIPMENT, CONDUIT, OR CABLING SHALL BE LOCATED BELOW BEAMS WITH LESS THAN 5" CLEARANCE FOR THE HVAC RETURN AIR.
- ALL ABANDONED AND UNUSED EQUIPMENT, INCLUDING, BUT NOT LIMITED TO PIPING AND DUCTWORK SHALL BE REMOVED.
- CONTRACTOR SHALL COORDINATE THE INSTALLATION AND ROUTING OF NEW PIPING AND DUCTWORK WITH EXISTING CONDITIONS IN THE FIELD.

**CAVAGNERO**  
ARCHITECTS

**SYSKA HENNESSY**  
**group**  
A member company of SH Group, Inc.  
 Syska Hennessy Group, Inc.  
 800 Corporate Pointe  
 Suite 200  
 Culver City, CA 90230  
 Tel: 310.312.0200  
 Fax: 310.665.0172  
 www.syska.com

REV	DATE	DESCRIPTION
	07/14/2016	100% SD
	08/04/2016	100% DD
	09/13/2016	50% CD
	11/08/2016	90% CD
	01/17/2017	PLAN CHECK #1
	03/09/2017	PERMIT SET
	06/14/2017	100% CD / CONFORMED SET


**EAST COUNTY COURTHOUSE**  
**ELEVATOR MODERNIZATION**  
 250 E Main St, El Cajon, CA 92020



**ENLARGED SIXTH FLOOR MECHANICAL PLAN**

**M4.06**

**1** ENLARGED SIXTH FLOOR MECHANICAL PLAN  
 M4.06 / 1/4" = 1'-0"



1 ENLARGED NINTH FLOOR MECHANICAL PLAN  
M4.09 / 1/4" = 1'-0"

**KEY NOTES**

- ROUTE (N) CONDENSATE DRAIN TO (E) APPROVED RECEPTACLE (FS/RD). MINIMUM 1" AIR GAP AT DISCHARGE.
- ALL EXISTING WALL/ROOF OPENINGS AND/OR LOUVERS WITHIN THE INDICATED ELEVATOR MACHINE ROOM SHALL BE DEMOLISHED AND SEALED.
- (N) REFRIGERANT LINES CONNECTING BETWEEN (N) AHU IN NINTH FLOOR ELEVATOR MACHINE ROOM TO (N) HP ON NINTH FLOOR ROOF. CONTRACTOR TO COORDINATE WITH FIELD CONDITIONS FOR EXACT PIPE ROUTING.
- (N) REFRIGERANT LINES CONNECTING BETWEEN (N) AHU IN SIXTH FLOOR ELEVATOR MACHINE ROOM TO (N) HP ON NINTH FLOOR ROOF. CONTRACTOR TO COORDINATE WITH FIELD CONDITIONS FOR EXACT PIPE ROUTING.
- (N) REFRIGERANT LINES CONNECTING BETWEEN (N) AHU IN NINTH FLOOR ELEVATOR MACHINE ROOM TO (N) HP ON NINTH FLOOR ROOF. CONTRACTOR TO COORDINATE WITH FIELD CONDITIONS FOR EXACT PIPE ROUTING.
- (N) REFRIGERANT LINES CONNECTING BETWEEN (N) AHU IN TENTH FLOOR ELEVATOR MACHINE ROOM TO (N) HP ON NINTH FLOOR ROOF. CONTRACTOR TO COORDINATE WITH FIELD CONDITIONS FOR EXACT PIPE ROUTING.

**GENERAL NOTES**

- EXISTING CONDITIONS ARE PER AS-BUILT DRAWINGS AND SYSKA SITE SURVEY. CONTRACTOR TO VERIFY EXISTING CONDITIONS PRIOR TO DEMOLITION AND INSTALLATION OF ANY WORK.
- INSPECT DUCT INSULATION ON ALL REUSED EXISTING DUCTWORK AFTER DEMOLITION AND REPAIR OR PROVIDE NEW INSULATION WHERE EXISTING IS DAMAGED OR MISSING.
- CONTRACTOR SHALL COORDINATE ALL HVAC AND BUILDING CONTROLS, SEQUENCES OF OPERATION, AND INTERLOCKS FOR THE SPACE WITH THE CHIEF BUILDING ENGINEER TO ENSURE THAT ALL WORK IS IN CONFORMANCE WITH THE BUILDING REQUIREMENTS.
- NO EQUIPMENT, CONDUIT, OR CABLING SHALL BE LOCATED BELOW BEAMS WITH LESS THAN 5" CLEARANCE FOR THE HVAC RETURN AIR.
- ALL ABANDONED AND UNUSED EQUIPMENT, INCLUDING, BUT NOT LIMITED TO PIPING AND DUCTWORK SHALL BE REMOVED.
- CONTRACTOR SHALL COORDINATE THE INSTALLATION AND ROUTING OF NEW PIPING AND DUCTWORK WITH EXISTING CONDITIONS IN THE FIELD.




REV	DATE	DESCRIPTION
	07/14/2016	100% SD
	08/04/2016	100% DD
	09/13/2016	50% CD
	11/08/2016	90% CD
	01/17/2017	PLAN CHECK #1
	03/09/2017	PERMIT SET
	06/14/2017	100% CD / CONFORMED SET

EAST COUNTY COURTHOUSE  
ELEVATOR MODERNIZATION  
250 E Main St, El Cajon, CA 92020



ENLARGED NINTH FLOOR MECHANICAL PLAN

M4.09



1 ENLARGED TENTH FLOOR MECHANICAL PLAN  
M4.10 1/4" = 1'-0"

**KEY NOTES**

- ROUTE (N) CONDENSATE DRAIN TO (E) APPROVED RECEPTACLE (FS/RD). MINIMUM 1" AIR GAP AT DISCHARGE.
- ALL EXISTING WALL/ROOF OPENINGS AND/OR LOUVERS WITHIN THE INDICATED ELEVATOR MACHINE ROOM SHALL BE DEMOLISHED AND SEALED.
- (N) REFRIGERANT LINES CONNECTING BETWEEN (N) AHU IN TENTH FLOOR ELEVATOR MACHINE ROOM TO (N) HP ON NINTH FLOOR ROOF. CONTRACTOR TO COORDINATE WITH FIELD CONDITIONS FOR EXACT PIPE ROUTING.\
- SEE DETAIL 2/M5.04 FOR SUPPLY GRILLE MOUNTING DETAIL.
- ROUTE DUCTWORK TIGHT TO STRUCTURE ABOVE.
- EXTEND RETURN AIR PLENUM UPWARD TOWARD STRUCTURE ABOVE. TERMINATE OPEN-ENDED WITHIN 1 FOOT OF STRUCTURE ABOVE. PROVIDE SCREEN MESH AT DUCT TERMINATION.

**GENERAL NOTES**

- EXISTING CONDITIONS ARE PER AS-BUILT DRAWINGS AND SYSKA SITE SURVEY. CONTRACTOR TO VERIFY EXISTING CONDITIONS PRIOR TO DEMOLITION AND INSTALLATION OF ANY WORK.
- INSPECT DUCT INSULATION ON ALL REUSED EXISTING DUCTWORK AFTER DEMOLITION AND REPAIR OR PROVIDE NEW INSULATION WHERE EXISTING IS DAMAGED OR MISSING.
- CONTRACTOR SHALL COORDINATE ALL HVAC AND BUILDING CONTROLS, SEQUENCES OF OPERATION, AND INTERLOCKS FOR THE SPACE WITH THE CHIEF BUILDING ENGINEER TO ENSURE THAT ALL WORK IS IN CONFORMANCE WITH THE BUILDING REQUIREMENTS.
- NO EQUIPMENT, CONDUIT, OR CABLING SHALL BE LOCATED BELOW BEAMS WITH LESS THAN 5" CLEARANCE FOR THE HVAC RETURN AIR.
- ALL ABANDONED AND UNUSED EQUIPMENT, INCLUDING, BUT NOT LIMITED TO PIPING AND DUCTWORK SHALL BE REMOVED.
- CONTRACTOR SHALL COORDINATE THE INSTALLATION AND ROUTING OF NEW PIPING AND DUCTWORK WITH EXISTING CONDITIONS IN THE FIELD.
- BRANCH DUCT SIZES PER SCHEDULE ON SHEET M0.08. TRANSITION AS REQUIRED AT POINT OF CONNECTION.




REV	DATE	DESCRIPTION
	07/14/2016	100% SD
	08/04/2016	100% DD
	09/13/2016	50% CD
	11/08/2016	90% CD
	01/17/2017	PLAN CHECK #1
	03/09/2017	PERMIT SET
	06/14/2017	100% CD / CONFORMED SET

EAST COUNTY COURTHOUSE  
ELEVATOR MODERNIZATION  
250 E Main St, El Cajon, CA 92020




ENLARGED TENTH FLOOR MECHANICAL PLAN


M4.10




**5** DUCT LINING INSTALLATION  
SCALE: NONE




**3** CIRCULAR DUCT WITH/WITHOUT VOLUME DAMPER  
SCALE: NONE




**1** HORIZONTAL ROUND DUCT SUPPORTS  
SCALE: NONE



**6** RECTANGULAR TO ROUND BRANCH TAP  
SCALE: NONE



**4** ACCEPTABLE ATTACHMENT  
SCALE: NONE



**2** DIFFUSER CONNECTION DETAIL  
SCALE: NONE



Syska Hennessy Group, Inc.  
800 Corporate Pointe  
Suite 200  
Culver City, CA 90230  
Tel: 310.312.0200  
Fax: 310.665.0172  
www.syska.com


REV	DATE	DESCRIPTION
	07/14/2016	100% SD
	08/04/2016	100% DD
	09/13/2016	50% CD
	11/08/2016	90% CD
	01/17/2017	PLAN CHECK #1
	03/09/2017	PERMIT SET
	08/14/2017	100% CD / CONFORMED SET

EAST COUNTY COURTHOUSE  
ELEVATOR MODERNIZATION  
250 E Main St, El Cajon, CA 92020




MECHANICAL DETAILS

M5.01




- NOTES:**
1. 1" MIN DROP REQUIRED. IF DRAW THRU, DROP=NEGATIVE STATIC PRESSURE AT FAN INLET.
  2. BLOW-THRU UNIT: LEG=DISCHARGE PRESSURE OF FAN + 1.
  3. DRAW-THRU UNIT: LEG=ONE HALF NEGATIVE INTERNAL STATIC PRESSURE AT FAN INLET + 1.
  4. MANUFACTURER RECOMMENDATION: LEG SIZE PER ACU/FCU/FCU/CU MANUFACTURER.
  5. ALLOW SUFFICIENT SPACE BELOW DRAIN PAN FOR TRAP.
  6. PITCH DRAIN FOR PROPER RUN-OFF AND DISCHARGE TO APPROVED RECEPTACLE.
  7. SUPPORT LENGTHY DRAIN LINES TO PREVENT SAG AND CONDENSATE OVERFLOW.
  8. MANUALLY PRIME FILL TRAP BEFORE START-UP TO FORM INITIAL DRAIN SEAL.
  9. CONTRACTOR TO VERIFY IF INTERNAL TRAP OCCUR IN WATER SOURCE HEAT PUMP.


**5 CONDENSATE DRAIN PIPING DETAIL**  
SCALE: NONE



**3 TYPICAL ELBOW DETAIL**  
SCALE: NONE




**1 ROUND VOLUME DAMPER LOW PRESSURE UP TO 14\"/>SCALE: NONE**



**PIPE SUPPORT SPACING SCHEDULE**


TYPE OF PIPE	SIZE	MAX. SPACING
STEEL	1 1/2" AND SMALLER	7 FT.
	2" AND LARGER	10 FT.
BRASS OR COPPER	3/4" AND SMALLER	5 FT.
	1" TO 1-1/4"	6 FT.
	1-1/2" TO 3"	7 FT.
	4" AND LARGER	10 FT.

**6 ROOF PIPE SUPPORT DETAIL**  
SCALE: NONE



- NOTES:**
1. FOR HANGERS SIZE AND SPACING, SEE CURRENT SMACNA HVAC DUCT CONSTRUCTION STANDARDS TABLE 5-1 REFERENCED ON THIS SHEET.
  2. DUCTS SHALL BE BRACED AND GUYED TO PREVENT LATERAL OR HORIZONTAL SWING PER UMC 603.2.5. FOR BRACING AND OTHER SEISMIC REQUIREMENTS, SEE GUIDELINES FOR SEISMIC RESTRAINTS OF MECHANICAL SYSTEMS AND PLUMBING PIPING SYSTEMS PUBLISHED BY SMACNA AND PPIC AS APPROVED BY CALIFORNIA CODE OF REGULATIONS (CCR), AND TITLE-24. ALSO REFER TO LATEST VERSION OF NATIONAL UNIFORM SEISMIC INSTALLATION GUIDELINES (NUSIG).
  3. STRAPS ARE GALVANIZED STEEL, RODS ARE UNCOATED OR GALVANIZED STEEL.
  4. PROVIDE MAX 6 FT SPACING FOR DUCT HANGERS.

**4 TYPICAL HORIZONTAL RECTANGULAR DUCT SUPPORTS**  
SCALE: NONE



**2 REFRIGERANT PIPING ROOF PENETRATION**  
SCALE: NONE




REV	DATE	DESCRIPTION
	07/14/2016	100% SD
	08/04/2016	100% DD
	09/13/2016	50% CD
	11/08/2016	90% CD
	01/17/2017	PLAN CHECK #1
	03/09/2017	PERMIT SET
	08/14/2017	100% CD / CONFORMED SET

**EAST COUNTY COURTHOUSE ELEVATOR MODERNIZATION**  
250 E Main St, El Cajon, CA 92020




**MECHANICAL DETAILS**





**3** **SPRING AND NEOPRENE ISOLATION/HANGER**  
SCALE: NONE




- NOTES:**
1. INSULATION ABOVE SADDLES SHALL BE FOAM/GLASS OF SAME THICKNESS AS PIPE INSULATION AND A COMPRESSIVE STRENGTH OF NOT LESS THAN 3,300 PSI. HANGERS ARE ALSO TYPICAL FOR UNINSULATED PIPING (WITHOUT INSULATION AND SADDLES.)
  2. HANGERS ARE ALSO TYPICAL FOR UNINSULATED PIPING (WITHOUT INSULATION AND SADDLES.)
  3. CONNECT TO TOP OR BOTTOM CHORD OF JOISTS BUT ONLY AT PANEL POINTS.
  4. C-CLAMPS ARE ACCEPTABLE FOR PIPE HANGER ASSEMBLIES ONLY IF RETAINING CLIP IS USED AND MSS-SP-69 STANDARD FOR PIPE HANGER ASSEMBLIES.
  5. ATTACH PER SMACNA.
  6. COORDINATE WITH STRUCTURE.

PIPE SUPPORT SPACING SCHEDULE		
TYPE OF PIPE	SIZE	MAX. SPACING
STEEL	1-1/2" AND SMALLER	7 FT
	2" AND LARGER	10 FT
BRASS OR COPPER	3/4" AND SMALLER	3 FT
	1" TO 1-1/4"	6 FT
COPPER	1-1/2" TO 3"	7 FT
	4" AND LARGER	10 FT


STEEL ROD SIZING SCHEDULE	
PIPE, IPS	ROD
2-1/2 IN	1/2 IN
3 IN	1/2 IN
4 IN	5/8 IN
6 IN	3/4 IN

**5** **PIPE HANGER DETAIL (TYPICAL)**  
SCALE: NONE




- NOTES:**
1. PIPE SLEEVE FOR EXTERIOR WALL ABOVE OR BELOW GRADE.
  2. FOR GAS SERVICE EXTENT SLEEVE 1" PAST INSIDE FACE OF WALL AND 4" PAST OUTSIDE FACE OF WALL.

**4** **PIPE SLEEVE THRU WALL**  
SCALE: NONE



**1** **AHU / HP DX PIPING DETAIL**  
SCALE: NONE



**2** **ALL DIRECTIONAL SUSPENDED EQUIPMENT**  
SCALE: NONE

**CAVAGNERO**  
ARCHITECTS

**SYSKA HENNESSY group**  
A member company of SH Group, Inc.  
Syska Hennessy Group, Inc.  
800 Corporate Pointe  
Suite 200  
Culver City, CA 90230  
Tel: 310.312.0200  
Fax: 310.665.0172  
www.syska.com

REV	DATE	DESCRIPTION
	07/14/2016	100% SD
	08/04/2016	100% DD
	09/13/2016	50% CD
	11/08/2016	90% CD
	01/17/2017	PLAN CHECK #1
	03/09/2017	PERMIT SET
	06/14/2017	100% CD / CONFORMED SET


**EAST COUNTY COURTHOUSE  
ELEVATOR MODERNIZATION**  
250 E Main St, El Cajon, CA 92020




**MECHANICAL DETAILS**

**NOTES:**

1. INVERTED TRAP AT HIGH POINT OF PUMPED DISCHARGE




**3 CONDENSATE DRAIN LINE CONNECTION (TYPICAL)**  
SCALE: NONE



- LIQUID AND GAS REFRIGERATION LINES TO INDOOR AHU UNIT.
- SEE REFRIGERANT PIPING ROOF PENETRATION DETAIL (2/M502) FOR FURTHER REQUIREMENT.
- NOTES:
1. ROOF EQUIPMENT PLATFORM BY CONTRACTOR.
  2. SHIM AS NECESSARY TO PROVIDE LEVEL PLATFORM.
  3. FASTEN TO BUILDING DECK STRUCTURE COORDINATE WITH STRUCTURAL ENG.
  4. EQUIPMENT PLATFORM SHALL BE APPROVED BY STRUCTURAL ENGINEER.
  5. WOOD JOISTS TO BE SIZED BY STRUCTURAL ENGINEER.
  6. ONLY FIRE RETARDANT TREATED WOOD TO BE USED FOR TYPE I-A CONSTRUCTION.

**1 CONDENSING UNIT MOUNTING DETAIL**  
SCALE: NONE



**2 SUPPLY GRILLE INSTALLATION DETAIL**  
SCALE: NONE



REV	DATE	DESCRIPTION
	07/14/2016	100% SD
	08/04/2016	100% DD
	09/13/2016	50% CD
	11/08/2016	90% CD
	01/17/2017	PLAN CHECK #1
	03/09/2017	PERMIT SET
	08/14/2017	100% CD / CONFORMED SET

**EAST COUNTY COURTHOUSE  
ELEVATOR MODERNIZATION**  
250 E Main St, El Cajon, CA 92020



**MECHANICAL DETAILS**

**M5.04**