

May 9, 2017

Pasadena Courthouse Elevation Modernization Bidders

Re: Addendum 1 Specifications Narrative

Attention Bidders:

The following is a summarized narrative of changes to the project specifications in Addendum 1, dated May, 9<sup>th</sup> 2017.

1. Section 01 11 000 1.2.5: Delete "Abatement of Asbestos Containing Materials" from scope of work.
2. Section 14211 1.05 C 1. "Provide security camera equipment for the custody elevators only".
3. Section 14211 1.05 C 2. ~~"Provide card readers where desired"~~.
4. Section 14211 1.19 "Maintenance Prior to and During the Modernization: Submit with base bid with a lump sum price. Warranty Maintenance: Submit with base bid a lump sum per the maintenance specification document and provide a break out monthly price should the warranty maintenance be extended past the three year period. Coverage shall be in accordance with Vertical Transportation Maintenance Specifications. "
5. Section 14211 2.02 A 32 ~~"Camera Provisions"~~
6. Section 14211 2.02 C 33 ~~"Camera Provisions"~~
7. Section 14211 2.05, Delete Part C
8. Section 14211 2.11 B " Provide new applied-type main car operating panel in compliance with applicable Code. Provide auxiliary car operating panel on passenger elevators only."
9. See appendix for Maintenance Specification.

Sincerely,

Steven Brummnd  
Mark Cavagnero Associates  
1045 Sansome Street  
San Francisco, CA 94111